

OPERATION MANUAL

WITHSTANDING VOLTAGE/
INSULATION RESISTANCE TESTER
TOS9200 Series

TOS9200 TOS9201

GPIB/RS-232C INTERFACE

INTERFACE				
GPIB ADDRESS : <u>4</u>				
SPEED : 19200		PARITY : NONE		
DATA : 8bit		STOP : 2bit		
GPIB	SPEED	DATA	PARITY	STOP



DANGER

This Tester generates high voltage.

- Any incorrect handling may cause death.
- Read Chapter 2 “PRECAUTIONS ON HANDLING” in TOS9200/9201 manual to prevent accident.
- Keep this manual together with the manual for TOS9200/9201, near the tester for easy access of the operator.

Use of Operation Manual

Please read through and understand this Operation Manual before operating the product. After reading, always keep the manual nearby so that you may refer to it as needed. When moving the product to another location, be sure to bring the manual as well.

If you find any incorrectly arranged or missing pages in this manual, they will be replaced. If the manual gets lost or soiled, a new copy can be provided for a fee. In either case, please contact Kikusui distributor/agent, and provide the “Kikusui Part No.” given on the cover.

This manual has been prepared with the utmost care; however, if you have any questions, or note any errors or omissions, please contact Kikusui distributor/agent.

Reproduction and reprinting of this operation manual, whole or partially, without our permission is prohibited.

Both unit specifications and manual contents are subject to change without notice.



Safety Symbols

For the safe use and safe maintenance of this product, the following symbols are used throughout this manual and on the product. Understand the meanings of the symbols and observe the instructions they indicate (the choice of symbols used depends on the products).



Indicates that a high voltage (over 1000 V) is used here. Touching the part causes a possibly fatal electric shock. If physical contact is required by your work, start work only after you make sure that no voltage is output here.

DANGER

Indicates an imminently hazardous situation which, if ignored, will result in death or serious injury.



Indicates a potentially hazardous situation which, if ignored, could result in death or serious injury.



Indicates a potentially hazardous situation which, if ignored, may result in damage to the product and other property.



Shows that the act indicated is prohibited.



Is placed before the sign “DANGER,” “WARNING,” or “CAUTION” to emphasize these. When this symbol is marked on the product, see the relevant sections in this manual.



Indicates a protective conductor terminal.



Indicates a chassis(frame) terminal.

Description of Contents

This manual is composed of the following chapters.

Chapter 1 TOS9200 GPIB/RS-232C Setup

This chapter describes the preparations to be made for remote control using the GPIB/RS-232C interface.

Chapter 2 GPIB and RS-232C

This chapter describes the GPIB/RS-232C interface and device messages.

Chapter 3 Messages and Registers

This chapter describes the device messages and registers.

Contents

Safety Symbols	I
Description of Contents	II
Chapter 1 TOS9200 GPIB/RS-232C Setup	
1.1 Preparing for GPIB Control	1-2
1.1.1 Connecting the GPIB cable	1-2
1.1.2 Setting the GPIB address	1-2
1.2 Preparing for RS-232C Control	1-3
1.2.1 Connecting the RS-232C cable	1-3
1.2.2 RS-232C settings	1-3
Chapter 2 GPIB and RS-232C	
2.1 Interface	2-1
2.1.1 GPIB interface	2-1
2.1.2 RS-232C interface	2-1
2.2 Messages and Terminators	2-3
2.2.1 Messages	2-3
2.2.2 Terminators	2-5
Chapter 3 Messages and Registers	
3.1 Register-Related Messages and General Purpose Messages	3-1
3.2 Messages Exclusively Used for AC Withstanding Voltage Testing	3-9
3.3 Messages Used Exclusively for DC Withstanding Voltage Testing	3-20
3.4 Messages Used Exclusively for Insulation Resistance Testing	3-29
3.5 Messages Common to All Tests	3-38
3.6 System-Related Messages	3-42
3.7 Memory-Related Messages	3-52
3.8 Program-Related Messages	3-63
3.9 Registers	3-70
3.10 Message List	3-74
3.10.1 Register-related messages and general messages	3-74
3.10.2 Messages for AC withstanding voltage testing	3-75
3.10.3 Messages for DC withstanding voltage testing	3-76
3.10.4 Messages for insulation resistance testing	3-77
3.10.5 Messages common to all tests	3-78
3.10.6 System-related messages	3-79
3.10.7 Memory-related messages	3-80
3.10.8 Program-related messages	3-82
Index	I-1

This is the operation manual designed to remotely control the TOS9200 Series with-standing voltage/insulation resistance tester using the GPIB or RS-232C interface. Attention is focused on the device message used in remote control.

Before starting remote control, prepare the Operation Manual for the TOS9200 Series and gain a full understanding of the instructions given in the manual.

- WARNING**
- In remote control, an external signal is used to turn a high voltage on/off, resulting in serious potential danger. To avoid the accidental generation of a high voltage and prevent workers from touching the device under testing (hereinafter referred to as a “DUT”), the high-voltage test leadwire, the high-voltage probe, and the output terminals when a high voltage is being output, provide full safety measures. Never conduct remote control without taking proper safety measures.

- NOTE**
- When an abnormal voltage occurs on the power line while a remote control operation using GPIB or RS-232C interface, the tester returns PROTECTION (line voltage monitoring) message. However, when the power of the tester is turned on while an abnormal voltage occurs already on the power line, the tester cannot return a message.




Fig.1-1 System configuration (example)

1.1 Preparing for GPIB Control

NOTE

- If settings are made so that the tester controls the earth continuity tester TOS6200, the GPIB interface cannot be used for remote control. For details, see “Controlling the TOS6200” in the Operation Manual for the Tester.

1.1.1 Connecting the GPIB cable

Turn off all POWER switches on the TOS9200 and other devices that are part of the GPIB system.


Connect the GPIB cable to the GPIB connector on the rear panel of the TOS9200/TOS9201.

1.1.2 Setting the GPIB address

To conduct remote control using the GPIB interface, a GPIB address must be set on the TOS9200/TOS9201. Do not use an address already set in the system.

To set a GPIB address, use the Interface Settings screen.

To display the Interface Settings screen (INTERFACE), press the SHIFT + SYSTEM(I/F) keys. The SYSTEM(I/F) key then lights up.



Set the GPIB address on the TOS9200/TOS9201 to 0 through 30.

NOTE

- The set GPIB address becomes valid after the TOS9200/9201 is restarted.

1. Using the F1 key (GPIB) or the ▲ ▼ ◀ ▶ keys, move the cursor to the GPIB ADDRESS.
2. Using the rotary knob, set a GPIB address.
3. On the TOS9200/TOS9201, turn off the POWER switch and then turn it on again.

1.2 Preparing for RS-232C Control

1.2.1 Connecting the RS-232C cable

Turn off all POWER switches on the TOS9200 and other devices that are part of the RS-232C system.

Connect the RS-232C cable to the RS-232C connector on the rear panel of the TOS9200/TOS9201.

1.2.2 RS-232C settings

To make settings, use the Interface Settings screen.

To display the Interface Settings screen (INTERFACE), press the SHIFT + SYSTEM(I/F) keys. The SYSTEM(I/F) key will then light up.

INTERFACE				
GPIB ADDRESS: _4				
SPEED : 19200		PARITY : NONE		
DATA : 8bit		STOP : 2bit		
GPIB	SPEED	DATA	PARITY	STOP
F1	F2	F3	F4	F5

NOTE

- When the interface settings are changed, they become valid after the TOS9200/9201 is restarted.

Setting the communication speed of the RS-232C interface

Three communication speeds are available for the RS-232C interface:

38,400 bps

19,200 bps

9,600 bps

1. Using the F2 key (SPEED) or the ▲ ▼ ◀ ▶ keys, move the cursor to SPEED.
2. Using the rotary knob, select 38,400, 19,200, or 9,600 bps.

Setting the data length of the RS-232C interface

The following two data lengths are available for the RS-232C interface:

7 bits

8 bits

1. Using the F3 key (DATA) or the ▲ ▼ ◀ ▶ keys, move the cursor to DATA.
2. Using the rotary knob, select 7 or 8.

Setting the parity of the RS-232C interface

The following three parities are available for the RS-232C interface:

NONE

ODD

EVEN

1. Using the F4 key (PARITY) or the ▲ ▼ ◀ ▶ keys, move the cursor to PARITY.
2. Using the rotary knob, select NONE, ODD, or EVEN.

Setting the stop bit of the RS-232C interface

The following two stop bits are available for the RS-232C interface:

1 bit

2 bits

1. Using the F5 key (STOP) or the ▲ ▼ ◀ ▶ keys, move the cursor to STOP.
2. Using the rotary knob, select 1 or 2.

This chapter describes the GPIB/RS-232C interface and device messages.

2.1 Interface

The tester is provided with a GPIB and RS-232C interface. Either can be selected.

2.1.1 GPIB interface

List of GPIB functions

Function	Subset	Description
Source handshaking	SH1	All functions provided
Acceptor handshaking	AH1	All functions provided
Talker	T6	All functions provided except for the talk-only function
Expansion talker	TE0	No function
Listener	L4	All functions provided except for the listen-only function
Expansion listener	LE0	No function
Service request	SR1	All functions provided
Remote local	RL1	All functions provided
Parallel polling	PP0	No function
Device clear	DC1	All functions provided
Device trigger	DT0	No function
Controller	C0	No function
Electrical interface	E1	Open collector

GPIB cables are available from Kikusui. Contact the supplier or your Kikusui agent.

GPIB cable: 1 m (Product No. 92080)

GPIB cable: 2 m (Product No. 92070)

GPIB cable: 4 m (Product No. 92090)

2.1.2 RS-232C interface


To use an RS-232C interface, the settings specified below must be made. For the setting procedure, see "1.2.2 RS-232C settings".

- RS-232C interface communication speed
- RS-232C interface data
- RS-232C interface parity
- RS-232C interface stop bit

Communication with the RS-232C must be regulated by flow control or using an acknowledge message. One-way transmission may make proper communication difficult. For details on acknowledge messages, see "2.2.1 Messages".

As the RS-232C cable, use an AT-type 9-pin D-SUB female-female cross cable.

RS-232C pin assignment



On the tester

Example of a cross cable


Fig.2-1 AT-type 9-pin connector

RS-232C flow control

Communication among tester controllers can be controlled by executing Xon and Xoff. These control codes are controlled by DC (Device Control) codes.

	Function	ASCII code
DC1	Send request	11h
DC3	Send Stop request	13h

Controlling transmission from the RS-232C terminal to the tester



Controlling transmission from the tester to the RS-232C terminal




Fig.2-2 Controlling transmission between the RS-232C terminal and the tester

2.2 Messages and Terminators

This section explains the terms used for communication between the computer (controller) and the tester (device). See Fig. 2-3.




Fig.2-3 Messages and terminators

2.2.1 Messages

Commands sent from the computer to the tester are referred to as “program messages.” Responses sent from the tester to the computer are referred to as “response messages.”

Each message is composed of a program-header block and a data block.

Program messages


Program messages are either “command messages” or “query messages.”

Command messages are used to execute specific functions of the tester and to change settings.


Query messages are used to inquire about the settings and status of the tester.

Describing a program message


- A space (ASCII: 20h) must be inserted between the program header and the data.



- If there are two or more pieces of data, connect them using “,” (ASCII: 2Ch).



- To connect program messages, use “;” (ASCII: 3Bh).




NOTE

- To describe data using hexadecimals, add “#H.”
(Example) The decimal 10 is expressed as “#H0A” in hexadecimal.
 - With the GPIB interface, add “@” to the end of a program message to maintain the HOLD OFF status until the message has been executed. However, in the event of a command message terminator with only EOI, use “@@”.
-

Acknowledge message (RS-232C)

Acknowledge messages are used only with the RS-232C interface. They are sent from the tester to the controller, and are used to confirm that the handling of a program message has been completed.



Acknowledge messages contain only a header composed of character strings in ASCII codes. The following two acknowledge messages are used:

- OK : Normal termination
- ERROR : Abnormality such as a syntax error

Using the SILENT command message, settings can be made to specify whether to return an acknowledge message.

2.2.2 Terminators

A program-message terminator is used to end a program message. A response-message terminator is used to end a response message.

- Program-message terminators
Any of the following can be used as a program-message terminator. No settings necessary:
CR+LF+EOI, LF, LF+EOI, CR+EOI
- Response-message terminators
By default, CR+LF+EOI is used. It can be changed to one of the following in accordance with the TRM command message. EOI is used only for GPIB.
CR+LF+EOI, LF+EOI, EOI, CR+EOI

NOTE

- EOI is exclusively used for GPIB as a program-message terminator and a response-message terminator.
-



Program messages and response messages supported by the tester are referred to as “device messages.”

The following describes each device message supported by the tester.

The symbol in parentheses following the device-message name is the abbreviation of the message name.

Special symbols and characters

The symbols and characters used to describe program messages and response messages are given below, along with their definitions.

Symbols and character	Description
< >	The parentheses indicate program data. In actual programming, do not use these parentheses.
{ }	Choose one from among the characters and numerals enclosed in parentheses and separated by “ : ”. In actual programming, do not use these parentheses.
_	Represents a space

3.1 Register-Related Messages and General Purpose Messages

Below, general purpose device messages and messages common to all modes are explained. general purpose device messages are used to set and reset each register, make inquiries, and specify a terminator.

*CLS

Resets the status byte register, event status register, device status register, protection register 1, protection register 2, fail register, invalid-setting register, and error register.

For each register, see "3.9 Registers".

Program message

- Syntax
Command message: *CLS

*ESR

The event status register is reset when it is read by the *ESR? Message.
For details on the event status register, see "3.9 Registers".

Program message

- Syntax
Query message: *ESR?

Response message

To reset, the contents of the event status register are returned to *ESR?.
(Example) When Bit 5 of the event status register is set, 32 is returned.

*IDN


Inquires about the model name and ROM version of the tester

Program message

- Syntax
Query message: *IDN?

Response message

The model name of the tester is returned to *IDN?, as follows:



*RST

Initializes the tester (to original factory-set settings). Note the settings made in the INTERFACE screen will not be initialized.

For details on initialization, see the relevant section of the operation manual for the tester.

Program message

- Syntax
Command message: *RST

*SRE

Sets or resets each bit of the service-request enable register, or inquires about the contents of the register.

For details on the service-request enable register, see "3.9 Registers".

Program message

- Syntax

Command message: *SRE_<value>

Query message: *SRE?

- Program data

Data format: Hexadecimal or decimal

Set value: 00H to FFH (0 to 255)

Resolution: 1H (1)

(Example) To set the service-request enable register to #50H,

*SRE #H50

Response message

To *SRE?, the contents of the service-request enable register are returned.

(Example) When Bit 5 and Bit 6 of the service-request enable register are set, 96 is returned.

*STB

Used to inquire about the contents of the status byte register.

For details on the status byte register, see "3.9 Registers".

Program message

- Syntax

Query message: *STB?

Response message

To *STB?, the contents of the status byte register are returned.

(Example) When Bit 5 and Bit 6 of the status byte register are set, 96 is returned.

CLR

Resets all registers exclusive of enable register and sets the STOP flag.

The same procedure is performed as when the GPIB bus line message DCL or SDC has been received.

Also used to perform the same processing as is performed by a DCL message from the RS-232C.

Program message

- Syntax
Command message: CLR

DSE

Sets or resets each bit of the device-status enable register, or inquires about the contents of the register.

For details on the device-status enable register, see "3.9 Registers".

Program message

- Syntax
Command message: DSE_<value>
Query message: DSE?
- Program data
Data format: Hexadecimal or decimal
Set value: 00H to FFH (0 to 255)
Resolution: 1H (1)
(Example) To set the device-status enable register to 01H,
DSE #H01

Response message

To DSE?, the contents of the device-status enable register are returned.

(Example) When Bit 5 of the device-status enable register is set, 32 is returned.

DSR

Used to inquire about the contents of the device status register.

For details on the device status register, see "3.9 Registers".

Program message

- Syntax
Query message: DSR?

Response message

To DSR?, the contents of the device status register are returned.

(Example) When Bit 5 of the device-status enable register is set, 32 is returned.

ERR

The error register is reset when read by the ERR? Message.

For details on the error register, see "3.9 Registers".

Program message

- Syntax

Query message: ERR?

Response message

To ERR?, the contents of the error register are returned.

(Example) When Bit 3 of the error register is set, 8 is returned.

FAIL

Inquires about the contents of the fail register.

For details on the fail register, see "3.9 Registers".

Program message

- Syntax

Query message: FAIL?

Response message

To FAIL?, the contents of the fail register are returned.

(Example) When Bit 4 of the fail register is set, 16 is returned.

FUNCTION (FUN)

Shifts the LCD to each mode (setting screen) and Inquires about the current mode (displayed screen).

Program message

- Syntax

Command message: FUNCTION_<value>

FUN_<value>

Query message: FUNCTION?

FUN?

- Program data
Data format: Integer
Set value: 0: ACW; 1: DCW; 2: IR; 3: AUTO TEST; 4: AUTO EDIT;
5: SYSTEM; 6: OFFSET ADJ; 7: INTERFACE

(Example) To change the contents of the program (to shift to AUTO EDIT)

FUN 4

Response message

To FUN?, the current mode is returned.

(Example) If the current mode is the AC withstanding voltage test, 0 is returned.

INVALID (INV)

Used to inquire about the contents of the invalid-setting register.

For details on the invalid-setting register, see "3.9 Registers".

Program message

- Syntax
Query message: INVALID?
INV?

Response message

To INV?, the contents of the invalid-setting register are returned.

(Example) When Bit 3 of the invalid-setting register is set, 8 is returned.

LOCAL (LOC)

Return to the LOCAL from the REMOTE state.

NOTE

- A wait of at least 500 ms is required before sending the next message after sending a LOCAL message.
-

Program message

- Syntax
Query message: LOCAL
LOC

PROTECTION (PROT)

Inquires about the contents of protection registers 1 and 2.
For details on the protection registers, see "3.9 Registers".

Program message

- Syntax

Query message: PROTECTION?
 PROT?

Response message

To PROT?, the contents of protection registers 1 and 2 are returned.

(Example) When Bit 3 and Bit 5 are set in protection registers 1 and 2, 8 and 32 are returned, respectively.

SILENT (SIL)

Used in control via RS-232C to specify whether to return an acknowledgment message to a message divided by the response message terminator. The SILENT? message is used to inquire about the set value that specifies whether to return an acknowledgment message.

As an acknowledgment message, either "OK" or "ERROR." is returned.

If an acknowledgment message is to be received, the RS-232C must be set at full duplex communication.

Full duplex communication: The transmission of data in two directions simultaneously. For full duplex settings, see the manual for your PC.

Program message

- Syntax

Command message: SILENT_<{0 | 1}>
 SIL_<{0 | 1}>

Query message: SILENT?
 SIL?

- Program data

Data format: Integer

Set value: 0: Return an acknowledge message.

 1: Do not return an acknowledge message.

(Example) To set "Do not return an acknowledge message,"

SIL 1

Response message

To SIL?, the set value for an acknowledge message is returned.

(Example) If the current settings are made to "Do not return an acknowledge message," 1 is returned.

START

Starts testing.

While a test program is running, it shifts the program from the step suspended due to a HOLD setting in the interval to the next step.

This command message is valid only in the test conditions set up (ACW, DCW, IR), offset measurement (OFFSET), or program (AUTO) screens. Switch screens using the FUNCTION message.

Program message

- Syntax
Command message: `START`

STOP

Stops a test. Also cancels FAIL, PASS (HOLD), and PROTECTION.

Program message

- Syntax
Command message: `STOP`

TRM

Used to set the response-message terminator, then inquire about the set value it. Note that the GPIB uni-line message “EOI” is effective only in GPIB communication.

Program message

- Syntax
Command message: `TRM_{0 | 1 | 2 | 3}>`
Query message: `TRM?`
- Program data
Data format: Integer
Set value: 0: CR/LF+EOI; 1: LF+EOI; 2: EOI; 3: CR+EOI

(Example) To set the response-message terminator to LF+EOI,

```
TRM 1
```

Response message

To `TRM?`, the preset response-message terminator is returned.

(Example) If the response-message terminator is set to LF+EOI, 1 is returned.

3.2 Messages Exclusively Used for AC Withstanding Voltage Testing

This section explains the messages used to check the test conditions and settings for AC withstanding voltage testing.

ACW:TESTV (A:TES)

Sets the test voltage for an AC withstanding voltage test, or inquires about the set or setting test voltage

NOTE

- This message is valid even during a test. However, make only fine voltage adjustment instead of making a large change to the voltage. A substantial change may activate the protective circuit to shift the tester to the protection status.
-

Program message

- Syntax

Command message: ACW:TESTV_<voltage>
A:TES_<voltage>

Query message: ACW:TESTV?
A:TES?

- Program data

Data format: Real number

Set value: 0.00 to 5.20 E3 (or 0 to 5200)

Resolution: 0.01

Unit: V

(Example) To set the test voltage to 5.00 kV,

A:TES 5.00E3

Response message

To A:TES?, the currently set test voltage is returned.

(Example) If the currently set test voltage is 2.50 kV, 2.50E3 is returned.

ACW:FREQUENCY (A:FREQ)

Sets the test frequency for an AC withstanding voltage test, or inquires about the set or setting test frequency.

Program message

- Syntax

Command message: `ACW:FREQUENCY_{50|60}>`
`A:FREQ_{50|60}>`

Query message: `ACW:FREQUENCY?`
`A:FREQ?`

- Program data

Data format: Character

Set value: 50, 60

Unit: Hz

(Example) To set the test frequency to 50 Hz,

`A:FREQ 50`

Response message

To `A:FREQ?`, the currently set test frequency is returned.

(Example) If the current test frequency is 60 Hz,
60 is returned.

ACW:LOWER (A:LOW)

Sets the lower current (LOWER) and ON/OFF of the lower judgment function for an AC withstanding voltage test. Also inquires about the lower current and the ON/OFF status of the lower judgment function.

Program message

- Syntax

Command message: `ACW:LOWER_{lower current, {ON|OFF}}>`
`A:LOW_{lower current, {ON|OFF}}>`

Query message: `ACW:LOWER?`
`A:LOW?`

- Program data *<lower current>*

Data format: Real number

Set value: 0.01 E-3 to 110 E-3

Resolution: 0.01 E-3 (0.01 E-3 to 9.99 E-3)
0.1 E-3 (10.0 E-3 to 99.9 E-3)
1 E-3 (100 E-3 to 110 E-3)

Unit: A

- Program data <{ON|OFF}>

Data format: Character

Set value: OFF (0), ON (1)

(Example) To set the lower current (LOWER) to 10.0 mA,

A: LOW 10.0E-3,ON

Response message

To A:LOW?, the currently set lower current and the ON/OFF status of the lower judgment function are returned as “lower current, 1/0.”

(Example) If the present lower current is 5.00 mA and the lower judgment function is OFF, 5.00E-3, 0 is returned.

ACW:UPPER (A:UPP)

Sets the upper current (UPPER) for an AC withstanding voltage test. Also inquires about the present upper current.



- If the upper current is set above 50 mA, the protective circuit may be activated. To prevent this, set the output time below 30 minutes and the pause to longer than the output time.
-

Program message

- Syntax

Command message: ACW:UPPER_<upper current>

A:UPP_<upper current>

Query message: ACW:UPPER?

A:UPP?

- Program data

Data format: Real number

Set value: 0.01 E-3 to 110 E-3

Resolution: 0.01 E-3 (0.01 E-3 to 9.99 E-3)

0.1 E-3 (10.0 E-3 to 99.9 E-3)

1 E-3 (100 E-3 to 110 E-3)

Unit: A

(Example) To set the upper current to 50.0 mA,

A:UPP 50.0E-3

Response message

To A:UPP?, the present upper current is returned.

(Example) If the present upper current is 80.0 mA, 80.0E-3 is returned.

ACW:TIMER (A:TIM)

Sets the test time (TEST TIME) and ON/OFF of the timer function for an AC withstanding voltage test. Also inquires about the current test time and the ON/OFF status of the timer function.

-
- ⚠ CAUTION** • If the upper current is set above 50 mA, the protective circuit may be activated. To prevent this, set the output time below 30 minutes and the pause to longer than the output time.
-

Program message

- Syntax

Command message: `ACW:TIMER_<test time, {ON|OFF}>`
`A:TIM_<test time, {ON|OFF}>`

Query message: `ACW:TIMER?`
`A:TIM?`

- Program data <test time>

Data format: Real number

Set value: 0.3 to 999

Resolution: 0.1 for 0.3 to 99.9, 1 for 100 to 999

Unit: s

- Program data <{ON|OFF}>

Data format: Character

Set value: OFF (0), ON (1)

(Example) To set the test time to 5 s,

`A:TIM 5,ON`

Response message

To `A:TIM?`, the current test time and the ON/OFF status of the timer function are returned as “test time, ON/OFF.”

(Example) If the current test time is 2.0 s and the timer function is set to OFF,

`2.0,0` is returned.

ACW:OFFSET (A:OFF)

Sets ON/OFF of the offset function for an AC withstanding voltage test. Also inquires about the ON/OFF status of the offset function.

Program message

- Syntax

Command message: ACW:OFFSET_<{ON|OFF}>
A:OFF_<{ON|OFF}>

Query message: ACW:OFFSET?
A:OFF?

- Program data

Data format: Character

Set value: OFF (0), ON (1)

(Example) To set the offset function to ON,

A:OFF 1

Response message

To A:OFF?, the ON/OFF status of the offset function is returned.

(Example) If the offset function is currently set to OFF,
0 is returned.

ACW:STARTV (A:STAR)

Sets the start voltage for an AC withstanding voltage test. Also inquires about the set or setting start voltage.

Program message

- Syntax

Command message: ACW:STARTV_<start voltage>
A:STAR_<start voltage>

Query message: ACW:STARTV?
A:STAR?

- Program data

Data format: Integer

Set value: 0 to 99

Resolution: 1

Unit: %

(Example) To set the start voltage to 10% of the test voltage,

A:STAR 10

Response message

To A:STAR?, the current start voltage is returned.

(Example) If the start voltage is currently set to 0%,
0 is returned.

ACW:RISETIME (A:RTIM)

Sets the voltage rise time (RISE TIME) for an AC withstanding voltage test. Also inquires about the set or setting voltage rise time.

Program message

- Syntax

Command message: ACW:RISETIME_<voltage rise time>
A:RTIM_<voltage rise time>

Query message: ACW:RISETIME?
A:RTIM?

- Program data

Data format: Real number

Set value: 0.1 to 200

Resolution: 0.1 for 0.1 to 99.9, 1 for 100 to 200

Unit: s

(Example) To set the voltage rise time to 1 s,

A:RTIM 1

Response message

To A:RTIM?, the current voltage rise time is returned.

(Example) If the voltage rise time is currently set to 2.0 s,
2.0 is returned.

ACW:FALLTIME (A:FTIM)

Sets the voltage fall time (FALL TIME) for an AC withstanding voltage test. Also inquires about the set or setting voltage fall time.

Program message

- Syntax

Command message: ACW:FALLTIME_<voltage fall time>
A:FTIM_<voltage fall time>

Query message: ACW:FALLTIME?
A:FTIM?

- Program data

Data format: Real number

Set value: 0.0 to 200

Resolution: 0.1 for 0.0 to 99.9, 1 for 100 to 200

Unit: s

(Example) To set the voltage fall time to 1 s,

A:FTIM 1

Response message

To A:FTIM?, the current voltage fall time is returned.

(Example) If the voltage fall time is currently set to 2.0 s,
2.0 is returned.

ACW:VRANGE (A:VRAN)

Sets the output-voltage range for an AC withstanding voltage test. Also inquires about the set or setting output range.

Program message

- Syntax

Command message: ACW:VRANGE_<{0 | 1}>
A:VRAN_<{0 | 1}>

Query message: ACW:VRANGE?
A:VRAN?

- Program data

Data format: Integer

Set value: 0: AUTO; 1: 5 kV

(Example) To set the output range to AUTO,

A:VRAN 0

Response message

To A:VRAN?, the output-voltage range is returned.

(Example) If the current output-voltage range is 5 kV,
1 is returned.

ACW:RESPONSE (A:RES)

Sets the current detection response speed (RESPONSE) for an AC withstanding voltage test.

Also inquires about the set or setting current detection response speed.

Program message

- Syntax

Command message: ACW:RESPONSE_<{0 | 1 | 2}>
A:RES_<{0 | 1 | 2}>

Query message: ACW:RESPONSE?
A:RES?

- Program data

Data format: Integer

Set value: 0: SLOW; 1: MID; 2: FAST

(Example) To set the current detection response speed to FAST,
 A:RES 2

Response message


To A:RES?, the preset current detection response speed is returned.

(Example) If the detection response speed is currently set to MID,
 1 is returned.


ACW:GND (A:GND)

Sets LOW/GUARD of the GND for an AC withstanding voltage test. Also inquires about the set or setting value of the GND.

- ⚠ WARNING**
- If it is not known whether a DUT or jig is grounded, never select GUARD. If GUARD is selected with a DUT grounded, the ammeter will be short-circuited, disabling measurement and posing grave danger. See Fig. 3-1 (B).
 - When GUARD is selected, do not connect the tester to devices grounded on a single side, such as Kikusui’s high-voltage digital voltmeter 149-10A and the current calibrator TOS1200. Otherwise, the ammeter will be short-circuited. See Fig. 3-1 (A).



(A) Connecting the 149-10A



(B) Selecting GUARD when the DUT is grounded

Fig.3-1 Dangerous connections

-
- ⚠ CAUTION** • When the tester's LOW terminal is connected to the HIGH or LOW terminal on the earth continuity tester TOS6200, the ammeter will make measurement errors if GUARD is selected. This is due to the fact that the resistor in the TOS6200 is connected in parallel with the tester's ammeter. To use the TOS6200, do not connect one terminal to another, or set the LOW terminal to LOW.
-

Program message

- Syntax
 - Command message: `ACW:GND_{GUARD|LOW}>`
`A:GND_{GUARD|LOW}>`
 - Query message: `ACW:GND?`
`A:GND?`
- Program data
 - Data format: Character
 - Set value: LOW (0), GUARD (1)
 - (Example) To set the GND to GUARD,
`A:GND 1`

Response message

- To A:GND?, the current GND setting is returned.
- (Example) If the GND is currently set to LOW,
0 is returned.

ACW:SCAN (A:SCAN)

Sets HIGH/LOW/OPEN for the scanner channel for an AC withstanding voltage test.

Also inquires about the set or setting value of the high-voltage scanner channel.

Program message

- Syntax
 - Command message: `ACW:SCAN_{channel, {H|L|O}}>`
`A:SCAN_{channel, {H|L|O}}>`
 - Query message: `ACW:SCAN?_{channel}>`
`A:SCAN?_{channel}>`
- Program data `<channel>`
 - Data format: Integer
 - Set value: 1 to 16
 - Resolution: 1
- Program data `<{H|L|O}>`
 - Data format: Character

Set value: O (0): OPEN; L (1): LOW; H (2): HIGH
(Example) To set scanner channel 1 to HIGH,
A:SCAN 1,H

Response message

To A:SCAN?2, the preset value for scanner channel 2 is returned.
(Example) If scanner channel 2 is currently set to OPEN,
0 is returned.

ACW:SCANW (A:SCANW)

Sets HIGH/LOW/OPEN for 16 scanner channels at a time using 16 bits for an AC withstanding voltage test. Also inquires about the current settings for all 16 channels.

Program message

- Syntax

Command message: ACW:SCANW_<setting 1, setting 2>
A:SCANW_<setting 1, setting 2>

Query message: ACW:SCANW?
A:SCANW?

- Program data <setting 1>

Data format: Integer
Set value: 0 to 65535 (#HFFFF)
Resolution: 1
LOW is represented by 0 and HIGH by 1.

- Program data <setting 2>

Data format: Integer
Set value: 0 to 65535 (#HFFFF)
Resolution: 1
OPEN is represented by 1 and NOT OPEN by 0.

(Example) To set scanner channels 1 through 4 to LOW, scanner channels 5 through 8 to HIGH, and the other channels to OPEN,

A:SCANW #H00F0,#HFF00

OPEN in setting 2 has priority over setting 1.

Response message

To A:SCANW?, the settings for all 16 channels are returned as “setting 1” and “setting 2” using 16 bits.

(Example) If scanner channels 1 through 5 are currently set to HIGH, channels 6 through 10 to OPEN, and the other channels to LOW,
31,992 is returned.

ACW:CONTACTCHECK (A:CCH)

Sets ON/OFF of the contact check function for an AC withstanding voltage test. Also inquires about the status of the function.

Program message

- Syntax

Command message: ACW:CONTACTCHECK_{ON|OFF}>
A:CCH_{ON|OFF}>

Query message: ACW:CONTACTCHECK?
A:CCH?

- Program data

Data format: Character

Set value: OFF (0), ON (1)

(Example) To set the contact check to ON,

A:CCH ON

Response message

To A:CCH?, the current setting for the contact check is returned.

(Example) If the contact check is currently set to ON,
1 is returned.

3.3 Messages Used Exclusively for DC Withstanding Voltage Testing

This section explains the messages used to check the test conditions and settings for DC withstanding voltage testing.

These messages are exclusively designed for the TOS9201 equipped with a DC withstanding voltage testing function.

With the TOS9200, these messages are invalid. However, they do not cause an error.

DCW:TESTV (D:TES)

Sets the test voltage for a DC withstanding voltage test. Also inquires about the set or setting test voltage

NOTE

- This message is valid even during a test. However, make only fine voltage adjustments rather than large changes to the voltage. A substantial change may activate the protective circuit to shift the tester to the protection status.
-

Program message

- Syntax

Command message: DCW:TESTV_<voltage>
D:TES_<voltage>

Query message: DCW:TESTV?
D:TES?

- Program data

Data format: Real number
Set value: 0.00 E3 to 6.10 E3 (or 0 to 6100)
Resolution: 0.01 E3
Unit: V

(Example) To set the test voltage to 5.00 kV,

D:TES 5.00E3

Response message

To D:TES?, the currently set test voltage is returned.

(Example) If the test voltage is currently set to 2.50 kV,
2.50E3 is returned.

DCW:LOWER (D:LOW)

Sets the lower current (LOWER) and ON/OFF of the lower judgment function for a DC withstanding voltage test. Also inquires about the lower current and the ON/OFF status of the lower judgment function.

Program message

- Syntax

Command message: DCW:LOWER_<lower current, {ON|OFF}>
D:LOW_<lower current, {ON|OFF}>

Query message: DCW:LOWER?
D:LOW?

- Program data <lower current>

Data format: Real number

Set value: 0.01 E-3 to 11.0 E-3

Resolution: 0.01 for 0.01 E-3 to 9.99 E-3, 0.1 for 10.0 E-3 to 11.0 E-3

Unit: A

- Program data <{ON|OFF}>

Data format: Character

Set value: OFF (0), ON (1)

(Example) To set the lower current to 1 mA,

D:LOW 1E-3,ON

Response message

To D:LOW?, the currently set lower current and the ON/OFF status of the lower judgment function are returned as “lower current, ON/OFF.”

(Example) If the lower current is currently set to 2.0 mA and the lower judgment function to OFF,

“2.00E-3,0” is returned.

DCW:UPPER (D:UPP)

Sets the upper current (UPPER) for a DC withstanding voltage test. Also inquires about the set or setting upper current.

⚠ CAUTION • If the upper current is set above 5 mA, the protective circuit may be activated. To prevent this, set the output time below 1 minute and the pause to longer than the output time.

Program message

- Syntax

Command message: DCW:UPPER_<upper current>
D:UPP_<upper current>

Query message: DCW:UPPER?
D:UPP?

- Program data

Data format: Real number

Set value: 0.01 E-3 to 11.0 E-3

Resolution: 0.01 for 0.01 E-3 to 9.99 E-3, 0.1 for 10.0 E-3 to 11.0 E-3

Unit: A

(Example) To set the upper current to 5 mA,

A:UPP 5E-3

Response message

To D:UPP?, the preset upper current is returned.

(Example) If the upper current is currently set to 2.00 mA,
2.00E-3 is returned.

DCW:TIMER (D:TIM)

Sets the test time (TEST TIME) and ON/OFF of the timer function for an DC withstanding voltage test. Also inquires about the current test time and the ON/OFF status of the timer function.

Program message

- Syntax

Command message: DCW:TIMER_<test time, {ON|OFF}>
D:TIM_<test time, {ON|OFF}>

Query message: DCW:TIMER?
D:TIM?

- Program data <test time>

Data format: Real number

- Set value: 0.3 to 999
 - Resolution: 0.1 for 0.3 to 99.9, 1 for 100 to 999
 - Unit: s
 - Program data <{ON|OFF}>
 - Data format: Character
 - Set value: OFF (0), ON (1)
- (Example) To set the test time to 5 s,
 D:TIM 5,ON

Response message

To D:TIM?, the current test time and the ON/OFF status of the timer function are returned as “test time, 1/0.”

(Example) If the test time is currently set to 2.0 s and the timer function to OFF, 2.0,0 is returned.

DCW:STARTV (D:STAR)

Sets the start voltage for a DC withstanding voltage test. Also inquires about the set or setting start voltage.

Program message

- Syntax
 - Command message: DCW:STARTV_<start voltage>
 D:STAR_<start voltage>
 - Query message: DCW:STARTV?
 D:STAR?
- Program data
 - Data format: Integer
 - Set value: 0 to 99
 - Resolution: 1
 - Unit: %

(Example) To set the start voltage to 10% of the test voltage,
 D:STAR 10

Response message

To D:STAR?, the current start voltage is returned.

(Example) If the start voltage is currently set to 0%, 0 is returned.

DCW:RISETIME (D:RTIM)

Sets the voltage rise time (RISE TIME) for a DC withstanding voltage test. Also inquires about the set or setting voltage rise time.

Program message

- Syntax

Command message: DCW:RISETIME_<voltage rise time>
D:RTIM_<voltage rise time>

Query message: DCW:RISETIME?
D:RTIM?

- Program data

Data format: Real number

Set value: 0.1 to 200

Resolution: 0.1 for 0.1 to 99.9, 1 for 100 to 200

Unit: s

(Example) To set the voltage rise time to 1 s,

D:RTIM 1

Response message

To D:RTIM?, the current voltage rise time is returned.

(Example) If the voltage rise time is currently set to 2.0 s,
2.0 is returned.

DCW:WAITTIME (D:WTIM)

Sets the WAIT TIME for a DC withstanding voltage test. Also inquires about the set or setting WAIT TIME.

Program message

- Syntax

Command message: DCW:WAITTIME_<WAIT TIME>
D:WTIM_<WAIT TIME>

Query message: DCW:WAITTIME?
D:WTIM?

- Program data

Data format: Real number

Set value: 0.3 to 10.0

Resolution: 0.1

Unit: s

(Example) To set the WAIT TIME to 1 s,

D:WTIM 1

Response message

To D:WTIM?, the currently set WAIT TIME is returned.

(Example) If the WAIT TIME is currently set to 2.0 s,
2 . 0 is returned.

DCW:GND (D:GND)

Sets LOW/GUARD of the GND for a DC withstanding voltage test. Also inquires about the set or setting value of the GND.

- ⚠ WARNING**
- If it is not known whether a DUT or jig is grounded, never select GUARD. If GUARD is selected with a DUT grounded, the ammeter will be short-circuited, disabling measurement and posing a grave danger. See Fig. 3-2 (B).
 - When GUARD is selected, do not connect the tester to devices grounded on a single side, such as Kikusui's high-voltage digital voltmeter 149-10A or current calibrator TOS1200. Otherwise, the ammeter will be short-circuited. See Fig. 3-2 (A).




Fig.3-2 Dangerous connections

-
- ⚠ CAUTION** • When the tester's LOW terminal is connected to the HIGH or LOW terminal of the earth continuity tester TOS6200, the ammeter will suffer measurement errors if GUARD is selected, as the resistor in the TOS6200 is connected in parallel with the tester's ammeter. To use the TOS6200, either do not connect one terminal to another, or set the LOW terminal to LOW.
-

Program message

- Syntax

Command message: DCW:GND_{GUARD|LOW}>
D:GND_{GUARD|LOW}>

Query message: DCW:GND?
D:GND?

- Program data

Data format: Character

Set value: LOW (0), GUARD (1)

(Example) To set the GND to GUARD,

D:GND 1

Response message

To D:GND?, the current GND setting is returned.

(Example) If the GND is currently set to LOW,
0 is returned.

DCW:SCAN (D:SCAN)

Sets HIGH/LOW/OPEN for the scanner channel in a DC withstanding voltage test. Also inquires about the current setting for the scanner channel.

Program message

- Syntax

Command message: DCW:SCAN_{channel, {H|L|O}}>
D:SCAN_{channel, {H|L|O}}>

Query message: DCW:SCAN?_{channel}>
D:SCAN?_{channel}>

- Program data <channel>

Data format: Integer

Set value: 1 to 16

Resolution: 1

- Program data <{H|L|O}>

Data format: Character

Set value: O (0): OPEN; L (1): LOW; H (2): HIGH

(Example) To set scanner channel 1 to HIGH,

D:SCAN 1,H

Response message

To D:SCAN?2, the preset value for scanner channel 2 is returned.

(Example) If scanner channel 2 is currently set to OPEN,
0 is returned.

DCW:SCANW (D:SCANW)

Sets HIGH/LOW/OPEN for 16 channels at a time using 16 bits in a DC withstanding voltage test. Also inquires about the current settings for all 16 channels.

Program message

- Syntax

Command message: DCW:SCANW_<setting 1, setting 2>
D:SCANW_<setting 1, setting 2>

Query message: DCW:SCANW?
D: SCANW?

- Program data <setting 1>

Data format: Integer

Set value: 0 to 65535 (#HFFFF)

Resolution: 1

LOW is represented by 0 and HIGH by 1.

- Program data <setting 2>

Data format: Integer

Set value: 0 to 65535 (#HFFFF)

Resolution: 1

OPEN is represented by 1 and NOT OPEN by 0.

(Example) To set scanner channels 1 through 4 to LOW, scanner channels 5 through 8 to HIGH, and the other channels to OPEN,

D:SCANW #H00F0,#HFF00

OPEN in setting 2 has priority over setting 1.

Response message

To D:SCANW?, the settings for all 16 channels are returned as “setting 1” and “setting 2” using 16 bits.

(Example) If scanner channels 1 through 5 are currently set to HIGH, channels 6 through 10 to OPEN, and the other channels to LOW,
“31,992” is returned.

DCW:CONTACTCHECK (D:CCH)

Sets ON/OFF of the contact check function for a DC withstanding voltage test. Also inquires about the status of the function.

Program message

- Syntax

Command message: DCW:CONTACTCHECK_{ON|OFF}>
D:CCH_{ON|OFF}>

Query message: DCW:CONTACTCHECK?
D:CCH?

- Program data

Data format: Character

Set value: OFF (0), ON (1)

(Example) To set the contact check to ON,

D:CCH ON

Response message

To D:CCH?, the current setting for the contact check is returned.

(Example) If the contact check is currently set to ON,
1 is returned.

3.4 Messages Used Exclusively for Insulation Resistance Testing

This section explains the messages used to check the test conditions and settings for insulation resistance testing.

IR:TESTV (I:TES)

Sets the test voltage for an insulation resistance test. Also inquires about the preset test voltage.

NOTE

- This message is valid even during a test. However, make only fine voltage adjustments rather than a large change to the voltage. A substantial change may activate the protective circuit to shift the tester to the protection status.
-

Program message

- Syntax

Command message: IR:TESTV_<voltage>
I:TES_<voltage>

Query message: IR:TESTV?
I:TES?

- Program data

Data format: Integer

Set value: 10 to 1020

Resolution: 1

Unit: V

(Example) To set the test voltage to 500 V,

I:TES 500

Response message

To I:TES?, the currently set test voltage is returned.

(Example) If the test voltage is currently set to 250 V,
250 is returned.

IR:LOWER (I:LOW)

Sets the lower resistance (LOWER) and ON/OFF of the lower judgment function for an insulation resistance test. Also inquires about the lower resistance and the ON/OFF status of the lower judgment function.

-
- ⚠ CAUTION** • If the lower or upper judgment function is OFF, no FAIL judgment is made for that function. With this setting, note that, a PASS judgment is made when the timer is turned on.
-

Program message

- Syntax

Command message: IR:LOWER_<lower resistance, {ON|OFF}>
I:LOW_<lower resistance, {ON|OFF}>

Query message: IR:LOWER?
I:LOW?

- Program data

Data format: Real number
Set value: 0.01 E6 to 9.99 E9
Resolution: 0.01 E6 (0.01 E6 to 9.99 E6)
0.1 E6 (10.0 E6 to 99.9 E6)
1 E6 (100 E6 to 999 E6)
0.01 E9 (1.00 E9 to 9.99 E9)
Unit: Ω

(Example) To set the lower resistance to 99.9 M Ω ,
I:LOW 99.9E6,1

Response message

To I:LOW?, the currently set lower resistance and the ON/OFF status of the lower judgment function are returned as “lower resistance, 1/0.”

(Example) If the lower resistance is currently set to 1.00 G Ω and the lower judgment function to OFF,
“1.00E9,0” is returned.

IR:UPPER (I:UPP)

Sets the upper resistance (UPPER) and ON/OFF of the upper judgment function for an insulation resistance test. Also inquires about the set or setting upper resistance and the ON/OFF status of the upper judgment function.

Program message

- Syntax

Command message: IR:UPPER_<upper resistance, {ON|OFF}>
I:UPP_<upper resistance, {ON|OFF}>

Query message: IR:UPPER?
I:UPP?

- Program data

Data format: Real number

Set value: 0.01 E6 to 9.99 E9

Resolution: 0.01 E6 (0.01 E6 to 9.99 E6)
0.1 E6 (10.0 E6 to 99.9 E6)
1 E6 (100 E6 to 999 E6)
0.01 E9 (1.00 E9 to 9.99 E9)

Unit: Ω

- Program data <{ON|OFF}>

Data format: Character

Set value: OFF (0), ON (1)

(Example) To set the upper resistance to 1.00 G Ω ,

I: UPP 1.00E9,1

Response message

To I:UPP?, the preset upper resistance and the ON/OFF status of the upper judgment function are returned as “upper resistance, 1/0.”

(Example) If the upper resistance is currently set to 5.00 G Ω and the upper judgment function to OFF,
“5.00E9,0” is returned.

IR:TIMER (I:TIM)

Sets the test time (TEST TIME) and ON/OFF of the timer function for an insulation resistance test. Also inquires about the current test time and the ON/OFF status of the timer function.

Program message

- Syntax

Command message: IR:TIMER_<test time, {ON|OFF}>
I:TIM_<test time, {ON|OFF}>

Query message: IR:TIMER?
I:TIM?

- Program data <test time>
Data format: Real number
Set value: 0.5 to 999
Resolution: 0.1 for 0.5 to 99.9, 1 for 100 to 999
Unit: s
- Program data <{ON|OFF}>
Data format: Character
Set value: OFF (0), ON (1)

(Example) To set the test time to 5 s,

I:TIM 5,ON

Response message

To I:TIM?, the current test time and the ON/OFF status of the timer function are returned.

(Example) If the test time is currently set to 2 s and the timer function to OFF, “2.0,0” is returned.

IR:RISETIME (I:RTIM)

Sets the voltage rise time (RISE TIME) for an insulation resistance test. Also inquires about the set or setting voltage rise time.

Program message

- Syntax
Command message: IR:RISETIME_<voltage rise time>
I:RTIM_<voltage rise time>
Query message: IR:RISETIME?
I:RTIM?

- Program data
Data format: Real number
Set value: 0.1 to 200
Resolution: 0.1 for 0.1 to 99.9, 1 for 100 to 200
Unit: s

(Example) To set the voltage rise time to 1 s,

I:RTIM 1

Response message

To I:RTIM?, the current voltage rise time is returned.

(Example) If the voltage rise time is currently set to 2.0 s, 2.0 is returned.

IR:WAITTIME (I:WTIM)

Sets the WAIT TIME for an insulation resistance test. Also inquires about the set or setting WAIT TIME.

Program message

- Syntax

Command message: `IR:WAITTIME_<WAIT TIME>`
`I:WTIM_<WAIT TIME>`

Query message: `IR:WAITTIME?`
`I:WTIM?`

- Program data

Data format: Real number

Set value: 0.3 to 10.0

Resolution: 0.1

Unit: s

(Example) To set the WAIT TIME to 1 s,

`I:WTIM 1`

Response message

To `I:WTIM?`, the currently set WAIT TIME is returned.


(Example) If the WAIT TIME is currently set to 2.0 s,
2.0 is returned.

IR:GND (I:GND)


Sets LOW/GUARD of the GND for an insulation resistance test. Also inquires about the set or setting value of the GND.



- **WARNING** If it is not known whether a DUT or jig is grounded, never select GUARD. If GUARD is selected with a DUT grounded, the ammeter is short-circuited, disabling measurement and posing grave danger. See Fig. 3-3 (B).
- When GUARD is selected, do not connect the tester to devices grounded on a single side, such as Kikusui's high-voltage digital voltmeter 149-10A or current calibrator TOS1200. Otherwise, the ammeter will be short-circuited. See Fig. 3-3 (A).



(A) Connecting the 149-10A



(B) Selecting GUARD when the DUT is grounded

Fig.3-3 Dangerous connections

- CAUTION** • When the tester's LOW terminal is connected to the HIGH or LOW terminal on the earth continuity tester TOS6200, the ammeter will suffer measurement errors if GUARD is selected, as the resistor in the TOS6200 is connected in parallel with the tester's ammeter. To use the TOS6200, either do not connect one terminal to another, or set the LOW terminal to LOW.

Program message

- Syntax

Command message: IR:GND_{GUARD | LOW}>
I:GND_{GUARD | LOW}>

Query message: IR:GND?
I:GND?

- Program data

Data format: Character

Set value: LOW (0), GUARD (1)

(Example) To set the GND to GUARD,

I:GND 1

Response message

To I:GND?, the current GND setting is returned.

(Example) If the GND is currently set to LOW,
0 is returned.

IR:SCAN (I:SCAN)

Sets HIGH/LOW/OPEN for the scanner channel in an insulation resistance test. Also inquires about the current setting of the high-voltage scanner channel.

Program message

- Syntax

Command message: IR:SCAN_<channel>, {H|L|O}>
I:SCAN_<channel>, {H|L|O}>

Query message: IR:SCAN?_<channel>
I:SCAN?_<channel>

- Program data <channel>

Data format: Integer

Set value: 1 to 16

Resolution: 1

- Program data <{H|L|O}>

Data format: Character

Set value: O (0): OPEN; L (1): LOW; H (2): HIGH

(Example) To set scanner channel 1 to HIGH,

I:SCAN 1,H

Response message

To I:SCAN? 2, the scanner channel 2 setting is returned.

(Example) If the scanner channel is currently set to OPEN,
0 is returned.

IR:SCANW (I:SCANW)

Sets HIGH/LOW/OPEN for 16 scanner channels at a time using 16 bits for an insulation resistance test. Also inquires about the settings for all 16 channels.

Program message

- Syntax

Command message: IR:SCANW_<setting 1, setting 2>
I:SCANW_<setting 1, setting 2>

Query message: IR:SCANW?
I:SCANW?

- Program data <setting 1>

Data format: Integer

Set value: 0 to 65535 (#HFFFF)

Resolution: 1

LOW is represented by 0 and HIGH by 1.

- Program data <setting 2>

Data format: Integer

Set value: 0 to 65535 (#HFFFF)

Resolution: 1

OPEN is represented by 1 and NOT OPEN by 0.

(Example) To set scanner channels 1 through 4 to LOW, scanner channels 5 through 8 to HIGH, and the other channels to OPEN,

```
I:SCANW #H00F0,#HFF00
```

OPEN in setting 2 has priority over setting 1.

Response message

To I:SCANW?, the settings for all 16 channels of the high-voltage scanner are returned as “setting 1” and “setting 2” using 16 bits.

(Example) If scanner channels 1 through 5 are currently set to HIGH, channels 6 through 10 to OPEN, and the other channels to LOW, 31,992 is returned.

IR:CONTACTCHECK (I:CCH)

Sets ON/OFF of the contact check function for an insulation resistance test. Also inquires about the status of the function.

Program message

- Syntax

Command message: IR:CONTACTCHECK_{ON|OFF}>
I:CCH_{ON|OFF}>

Query message: IR:CONTACTCHECK?
I:CCH?

- Program data

Data format: Character

Set value: OFF (0), ON (1)

(Example) To set the contact check to ON,

I:CCH ON

Response message

To I:CCH?, the current setting for the contact check is returned.

(Example) If the contact check is currently set to ON,
1 is returned.

3.5 Messages Common to All Tests

This section explains the messages commonly used in all tests.

VDATA (VDAT)

Inquires about the monitor voltage for each test. During the test, the real-time voltage is returned. After the test, the previous test voltage is returned.

Program message

- Syntax
Query message: VDATA?
 VDAT?

Response message

To VDAT?, the monitor voltage is returned for ACW in an AC withstanding voltage test, for DCW in a DC withstanding voltage test, and for IR in an insulation resistance test.

(Example) If the current monitor voltage in an AC withstanding voltage test is 1.5 kV,
1.50E3 is returned.

NOTE

- In insulation resistance testing with the lower judgment function off, even if settings are made so that the test voltage divided by the lower resistance exceeds 1.1 mA, testing can be performed. However, when the voltage value which is out of the range of $\pm(10\%$ of setting +50 V) is detected during the test, the measurement voltage value flashes on the LCD.
In this case, -1 is returned.
-

IDATA (IDAT)

Inquires about the monitor current.

During the test, the measured normal value or the maximum value is returned, depending on the MEAS MODE setting in the system settings. After the test, the previous test current is returned.

Program message

- Syntax
Query message: IDATA?
 IDAT?

Response message

To IDAT?, the monitor current is returned for ACW in an AC withstanding voltage test and for DCW in a DC withstanding voltage test.

(Example) If the present monitor current in an AC withstanding voltage test is 10.0 mA,
10.0E-3 is returned.

RDATA (RDAT)

Inquires about the monitor resistance

During the test, the measured normal value or the minimum value is returned, depending on the MEAS MODE setting in the system settings. After the test, the previous monitor resistance is returned.

Program message

- Syntax

Query message: RDATA?
RDAT?

Response message

To RDAT?, the monitor resistance is returned for IR in an insulation resistance test.

(Example) If the current monitor resistance is 10.0 MΩ,
10.0E6 is returned.

NOTE

- In insulation resistance testing, when the resistance value to exceed 9.99 GΩ is detected.
9.99 GΩ < 99.9 GΩ :The returned resistance value is not warranted.
99.9 GΩ ≤ : “99.9” flashes on the LCD and -1 is returned.
-

REALDATA (REAL)

Inquires about the real current.

During the test, the real-time real current is returned. After the test, the previous real current is returned.

Program message

- Syntax

Query message: REALDATA?
REAL?

Response message

To REAL?, the present real current is returned.

(Example) If the present real current is 1 mA,
1E-3 is returned.

IMAGDATA (IMAG)

Inquires about the imaginary current. During the test, the real-time imaginary current is returned. After the test, the previous imaginary current is returned.

Program message

- Syntax
Query message: IMAGDATA?
 IMAG?

Response message

To IMAG?, the present imaginary current is returned.
(Example) If the present imaginary current is 20 μA ,
20E-6 is returned.

TIME

Inquires about the test time elapsed (the remaining time when the timer function is on) and the test status

Program message

- Syntax
Query message: TIME?

Response message

To TIME?, the time elapsed (the remaining time when the timer function is on) and the test status are returned as “time, status.”
Rising (Rise): 0; Testing (Test): 1; Falling (Fall): 2; Ending (End): 3
(Example) If the time elapsed (or the remaining time) is 7.0 s and the test is under way,
7.0, 1 is returned.

MON

Inquires about each monitor value

Program message

- Syntax
Query message: MON?

Response message

To MON?, the current monitor value is returned.
When no test is under way, the previous test results are returned.

Returning in AC withstanding voltage testing

Test type (0: ACW), monitor voltage, monitor current NORM, monitor current MAX, real current, imaginary current, elapsed (remaining) time, test status (0: Rise/1: Test/2: Fall/3: End)

Returning in DC withstanding voltage testing

Test type (1: DCW), monitor voltage, monitor current NORM, monitor current MAX, monitor resistance MIN, elapsed (remaining) time, test status (0: Rise/1: Test/3: End)

Returning in insulation resistance testing

Test type (2: IR), monitor voltage, monitor resistance NORM, monitor resistance MIN, monitor current, 0, elapsed (remaining) time, test status (0: Rise/1: Test/3: End)

(Example) If an AC withstanding voltage test is under way at a monitor voltage of 2.50 kV, monitor current NORM of 5.2 mA, monitor current MAX of 12 mA, real current of 5 mA, imaginary current of 10 μ A, and remaining time of 2.6 s,

“0, 2.5E3, 5.2E-3, 12E-3, 5E-3, 10E-6, 2.6, 1” is returned.

NOTE

- In insulation resistance testing with the lower judgment function off, even if settings are made so that the test voltage divided by the lower resistance exceeds 1.1 mA, testing can be performed. However, when the voltage value which is out of the range of $\pm(10\%$ of setting +50 V) is detected during the test, the measurement voltage value flashes on the LCD. In this case, -1 is returned.
 - In insulation resistance testing, when the resistance value to exceed 9.99 G Ω is detected.
9.99 G Ω < 99.9 G Ω : The returned resistance value is not warranted.
99.9 G Ω \leq : “99.9” flashes on the LCD and -1 is returned.
-

SCANTYPE (STYP)

Inquires about the number of valid connected channels and the model name of the scanner

Program message

- Syntax

Query message: SCANTYPE?
STYP?

Response message

To STYP?, the number of valid channels and the model name of the scanner are returned as follows:

Number of valid channels, scanner 1, scanner 2, scanner 3, scanner 4

0: None; 1: TOS9220; 2: TOS9221

(Example) If there are 12 valid channels and scanners TOS9220, TOS9220, and TOS9221 (in that order, from the nearest to the tester) are connected without a fourth scanner connected,

“12, 1, 1, 2, 0” is returned.

CFAILCH (CFCH)

Inquires about the channel in the C FAIL status

Program message

- Syntax

Query message: CFAILCH?
 CFCH?

Response message

To CFCH?, the channel in the CONTACT FAIL status is returned.

(Example) If channel 12 is currently in the CONTACT FAIL status,
12 is returned.

3.6 System-Related Messages

This section describes the messages to be set on the system screen.

MEASMODE (MMOD)

Sets the display mode (MEAS MODE) of the measured current (or measured resistance). Also inquires about the display mode of the measured current (or measured resistance).

Program message

- Syntax

Command message: MEASMODE_<{NORM|MAX}>
 MMOD_<{NORM|MAX}>

Query message: MEASMODE?
 MMOD?

- Program data

Data format: Character

Set value: NORM: Real Time; MAX: Max Hold (Min Hold)

(Example) To set the display mode of the measured current (or resistance) to Max Hold (Min Hold for resistance),

MMOD MAX

Response message

To MMOD?, the present display mode of the measured current (or resistance) is returned as 0 for NORM and 1 for MAX.

(Example) If the display mode of the present measured current is set to Real Time,
0 is returned.

PASSHOLD (PHOL)

Sets the PASS hold time in a PASS judgment. Also inquires about the current PASS hold time.

Program message

- Syntax

Command message: `PASSHOLD_<set value>`
`PHOL_<set value>`

Query message: `PASSHOLD?`
`PHOL?`

- Program data

Data format: Real number, character

Set value: 0.2 to 10.0, HOLD

Unit: s

(Example) To set the PASS hold time to HOLD,
`PHOL HOLD`

Response message

To `PHOL?`, the current PASS hold time is returned.

(Example) If the current PASS hold time is 0.5 s,
`0.5` is returned.

BUZZERVOL (BVOL)

Set the buzzer volume. Also inquires about the current buzzer volume.

Program message

- Syntax

Command message: `BUZZERVOL_<set value>`
`BVOL_<set value>`

Query message: `BUZZERVOL?`
`BVOL?`

- Program data

Data format: Integer

Set value: 0 to 10

Resolution: 1

(Example) To set the buzzer volume to 5,
`BVOL 5`

Response message

To BVOL?, the current volume is returned.

(Example) If the current buzzer volume is 3,
3 is returned.

CONTRAST (CON)

Sets the LCD contrast. Also inquires about the current LCD contrast.

Program message

- Syntax

Command message: `CONTRAST_<set value>`
`CON_<set value>`

Query message: `CONTRAST?`
`CON?`

- Program data

Data format: Integer

Set value: 0 to 10

Resolution: 1

(Example) To set the LCD contrast to 5,
`CON 5`

Response message

To CON?, the current LCD contrast is returned.

(Example) If the current LCD contrast is 6,
6 is returned.

MOMENTARY (MOM)

Sets the start momentary function (MOMENTARY). Also inquires about the current start momentary setting.

Program message

- Syntax

Command message: `MOMENTARY_<{ON | OFF}>`
`MOM_<{ON | OFF}>`

Query message: `MOMENTARY?`
`MOM?`

- Program data

Data format: Character

Set value: OFF (0), ON (1)

(Example) To set the start momentary function to OFF,
MOM OFF

Response message

To MOM?, the current start momentary setting is returned.

(Example) If the start momentary function is currently ON,
1 is returned.

FAILMODE (FMOD)

Sets the FAIL mode (FAIL MODE). Also inquires about the current FAIL mode setting.

Program message

- Syntax

Command message: FAILMODE_<{ON | OFF}>
FMOD_<{ON | OFF}>

Query message: FAILMODE?
FMOD?

- Program data

Data format: Character

Set value: OFF (0), ON (1)

(Example) To set the FAIL mode to OFF,
FMOD OFF

Response message

To FMOD?, the current FAIL mode setting is returned.

(Example) If the FAIL mode function is currently ON,
1 is returned.

DOUBLE ACTION (DAC)

Sets the double-action mode (DOUBLE ACTION). Also inquires about the current double-action mode setting.

Program message

- Syntax

Command message: DOUBLEACTION_<{ON | OFF}>
DAC_<{ON | OFF}>

Query message: DOUBLEACTION?
DAC?

- Program data

Data format: Character

Set value: OFF (0), ON (1)
(Example) To set the double-action mode to OFF,
DAC OFF

Response message

To DAC?, the current double-action mode setting is returned.
(Example) If the double-action mode is currently ON,
1 is returned.

SIGHVON (SHV)

Sets H.V ON of Status Signal Output. Also inquires about the H.V ON setting.

Program message

- Syntax

Command message: SIGHVON_{ON|OFF}>
SHV_{ON|OFF}>

Query message: SIGHVON?
SHV?

- Program data

Data format: Character

Set value: OFF (0), ON (1)

(Example) To set H.V ON of Status Signal Output to OFF,
SHV OFF

Response message

To SHV?, the current H.V ON setting for Status Signal Output is returned.
(Example) If H.V ON for Status Signal Output is currently set to ON,
1 is returned.

SIGTEST (STES)

Sets TEST for Status Signal Output. Also inquires about the current TEST setting.

Program message

- Syntax

Command message: SIGTEST_{ON|OFF}>
STES_{ON|OFF}>

Query message: SIGTEST?
STES?

- Program data

Data format: Character

Set value: OFF (0), ON (1)
(Example) To set TEST for Status Signal Output to OFF,
STES OFF

Response message

To STES?, the current TEST setting for Status Signal Output is returned.
(Example) If the TEST status of Status Signal Output is currently set to ON,
1 is returned.

SIGPASS (SPAS)

Sets PASS for Status Signal Output. Also inquires about the current PASS setting.

Program message

- Syntax

Command message: SIGPASS_<{ON|OFF}>
SPAS_<{ON|OFF}>

Query message: SIGPASS?
SPAS?

- Program data

Data format: Character

Set value: OFF (0), ON (1)

(Example) To set the PASS status of Status Signal Output to OFF,
SPAS OFF

Response message

To SPAS?, the current PASS setting for Status Signal Output is returned.
(Example) If the PASS status of Status Signal Output is currently set to ON,
1 is returned.

SIGUFAIL (SUF)

Sets U FAIL for Status Signal Output. Also inquires about the current U FAIL setting.

Program message

- Syntax

Command message: SIGUFAIL_<{ON|OFF}>
SUF_<{ON|OFF}>

Query message: SIGUFAIL?
SUF?

- Program data

Data format: Character

Set value: OFF (0), ON (1)

(Example) To set the U FAIL status of Status Signal Output to OFF,

SUF OFF

Response message

To SUF?, the current U FAIL setting for Status Signal Output is returned.

(Example) If the U FAIL status of Status Signal Output is currently set to ON, 1 is returned.

SIGLFAIL (SLF)

Sets L FAIL for Status Signal Output. Also inquires about the current LOW FAIL setting.

Program message

- Syntax

Command message: SIGLFAIL_<{ON|OFF}>
SLF_<{ON|OFF}>

Query message: SIGLFAIL?
SLF?

- Program data

Data format: Character

Set value: OFF (0), ON (1)

(Example) To set the L FAIL status of Status Signal Output to OFF,

SLF OFF

Response message

To SLF?, the current L FAIL setting for Status Signal Output is returned.

(Example) If the L FAIL status of Status Signal Output is currently set to ON, 1 is returned.

SIGREADY (SREA)

Sets READY for Status Signal Output. Also inquires about the current READY setting.

Program message

- Syntax

Command message: SIGREADY_<{ON|OFF}>
SREA_<{ON|OFF}>

Query message: SIGREADY?
SREA?

- Program data

Data format: Character

Set value: OFF (0), ON (1)

(Example) To set the READY status of Status Signal Output to OFF,
SREA OFF

Response message

To SREA?, the current READY setting for Status Signal Output is returned.

(Example) If the READY status of Status Signal Output is currently set to ON,
1 is returned.

SIGPROTECTION (SPR)

Sets PROTECT for Status Signal Output. Also inquires about the current PROTECT setting.

Program message

- Syntax

Command message: SIGPROTECTION_{ON | OFF}>
SPR_{ON | OFF}>

Query message: SIGPROTECTION?
SPR?

- Program data

Data format: Character

Set value: OFF (0), ON (1)

(Example) To set the PROTECT status of Status Signal Output to OFF,
SPR OFF

Response message

To SPR?, the current PROTECT setting for Status Signal Output is returned.

(Example) If the PROTECT status of Status Signal Output is currently set to ON,
1 is returned.

SIGPOWERON (SPOW)

Sets POWER ON for Status Signal Output. Also inquires about the current POWER ON setting.

Program message

- Syntax

Command message: SIGPOWERON_<{ON|OFF}>
SPOW_<{ON|OFF}>

Query message: SIGPOWERON?
SPOW?

- Program data

Data format: Character

Set value: OFF (0), ON (1)

(Example) To set the POWER ON status of Status Signal Output to OFF,

SPOW OFF

Response message

To SPOW?, the current POWER ON setting for Status Signal Output is returned.

(Example) If the POWER ON status of Status Signal Output is currently set to ON, 1 is returned.

SIGCFAIL (SCF)

Sets C FAIL for Status Signal Output. Also inquires about the current C FAIL setting.

Program message

- Syntax

Command message: SIGCFAIL_<{ON|OFF}>
SCF_<{ON|OFF}>

Query message: SIGCFAIL?
SCF?

- Program data

Data format: Character

Set value: OFF (0), ON (1)

(Example) To set the C FAIL status of Status Signal Output to OFF,

SCF OFF

Response message

To SCF?, the current C FAIL setting for Status Signal Output is returned.

(Example) If the CONTACT FAIL status of Status Signal Output is currently set to ON, 1 is returned.

COMMENT (COM)

Inputs a comment (memo). Also inquires about the current comment. Up to three lines can be entered, with a maximum of 12 characters per line.

Program message

- Syntax

Command message: `COMMENT_<"1st line", "2nd line",
"3rd line">`

`COM_<"1st line", "2nd line",
"3rd line">`

Query message: `COMMENT?
COM?`

- Program data

Data format: String

Set value: ASCII Code 20H to 7EH

(Except 22H ("), 27H ('), 2CH (,), 3BH (;), and 40H (@))

Put Set value in 22Hs (".)

(Example) To enter "KIKUSUI" in the 1st line, a blank in the 2nd line, and "TOS9201" in the 3rd line,

```
COM "KIKUSUI", " ", "TOS9201"
```

Response message

To COM?, the current comment is returned.

(Example) If "KIKUSUI" is entered in the 1st line and "123456789ABCDEFGHIJK" in the 3rd line, with no entry in the 2nd line, the following comment is returned (_ = space):

```
KIKUSUI _____ , _____ ,  
123456789ABCDEFGHIJK
```

3.7 Memory-Related Messages

This section explains the messages used in connection with memory.

ACW:RECALL (A:REC)

Recalls the contents of memory stored in an AC withstanding voltage test

Program message

- Syntax

Command message: ACW:RECALL_<memory number>
A:REC_<memory number>

- Program data

Data format: Integer
Set value: 0 to 99
Resolution: 1

(Example) To recall memory 10 for AC withstanding voltage testing,

A:REC 10

DCW:RECALL (D:REC)

Recalls the contents of memory stored in a DC withstanding voltage test

Program message

- Syntax

Command message: DCW:RECALL_<memory number>
D:REC_<memory number>

- Program data

Data format: Integer
Set value: 0 to 99
Resolution: 1

(Example) To recall memory 10 for DC withstanding voltage testing,

D:REC 10

IR:RECALL (I:REC)

Recalls the contents of memory stored in an insulation resistance test

Program message

- Syntax

Command message: IR:RECALL_<memory number>
I:REC_<memory number>

- Program data

Data format: Integer
Set value: 0 to 99
Resolution: 1

(Example) To recall memory 10 for insulation resistance testing,

I:REC 10

ACW:STORE (A:STOR)

Stores the current settings for an AC withstanding voltage test. Note that the memory name is not stored (the existing memory name is not replaced).

Program message

- Syntax

Command message: ACW:STORE_<memory number>
A:STOR_<memory number>

- Program data

Data format: Integer
Set value: 0 to 99
Resolution: 1

(Example) To store the current settings for an AC withstanding voltage test to memory 10,

A:STOR 10

DCW:STORE (D:STOR)

Stores the current settings for a DC withstanding voltage test. Note that the memory name is not stored (the existing memory name is not replaced).

Program message

- Syntax

Command message: `DCW:STORE_<memory number>`
`D:STOR_<memory number>`

- Program data

Data format: Integer

Set value: 0 to 99

Resolution: 1

(Example) To store the current settings for a DC withstanding voltage test to memory 10,

`D:STOR 10`

IR:STORE (I:STOR)

Stores the current settings for an insulation resistance test. Note that the memory name is not stored (the existing memory name is not replaced).

Program message

- Syntax

Command message: `IR:STORE_<memory number>`
`I:STOR_<memory number>`

- Program data

Data format: Integer

Set value: 0 to 99

Resolution: 1

(Example) To store the current settings for an insulation resistance test to memory 10,

`I:STOR 10`

ACW:MEMORY (A:MEM)

Stores the test conditions for an AC withstanding voltage test to a specified memory number. Also inquires about the contents of the memory with the specified number.

Program message

- Syntax

Command message: `ACW:MEMORY_<memory number>, "memory name", test voltage, lower current, upper current, test time, frequency{50|60}, lower judgment {ON|OFF}, offset{ON|OFF}, timer{ON|OFF}, start voltage, voltage rise time, voltage fall time, voltage range{0|1}, current-detection response speed{0|1|2}, GND{GUARD|LOW}, contact check{ON|OFF}, scanner Hi/Low, scanner Open`

Query message: `ACW:MEMORY?`
`A:MEM?`

- Program data `<memory number>`

Data format: Integer
Set value: 0 to 99
Resolution: 1

- Program data `<memory name>`

Data format: String
Set value: ASCII Code 20H to 7EH (up to 12 characters)
(Except 22H ("), 27H ('), 2CH (,), 3BH (;), and 40H (@))
Put Set value in 22Hs (".)

- Program data `<test voltage>`

Data format: Real number
Set value: 0.00 to 5.20 E3
Resolution: 0.01 E3
Unit: V

- Program data `<lower current>`

Data format: Real number
Set value: 0.01 E-3 to 110 E-3
Resolution: 0.01 E-3 (0.01 E3 to 9.99 E-3)
0.1 E-3 (10.0 E-3 to 99.9 E-3)
1 E-3 (100 E-3 to 110 E-3)
Unit: A

- Program data `<upper current>`

Data format: Real number
Set value: 0.01 E-3 to 110 E-3

- Resolution: 0.01 E-3 (0.01 E3 to 9.99 E-3)
0.1 E-3 (10.0 E-3 to 99.9 E-3)
1 E-3 (100 E-3 to 110 E-3)
- Unit: A
- Program data <*test time*>
 - Data format: Real number
 - Set value: 0.3 to 999
 - Resolution: 0.1 for 0.3 to 99.9, 1 for 100 to 999
 - Unit: s
 - Program data <*frequency*>
 - Data format: Character
 - Set value: 50, 60
 - Unit: Hz
 - Program data <*lower judgment*{ON|OFF}>
 - Data format: Character
 - Set value: OFF, ON (0, 1)
 - Program data <*offset*{ON|OFF}>
 - Data format: Character
 - Set value: OFF, ON (0, 1)
 - Program data <*timer*{ON|OFF}>
 - Data format: Character
 - Set value: OFF, ON (0, 1)
 - Program data <*start voltage*>
 - Data format: Integer
 - Set value: 1 to 99
 - Resolution: 1
 - Unit: %
 - Program data <*voltage rise time*>
 - Data format: Real number
 - Set value: 0.1 to 200
 - Resolution: 0.1 for 0.1 to 99.9, 1 for 100 to 200
 - Unit: s
 - Program data <*voltage fall time*>
 - Data format: Real number
 - Set value: 0.0 to 200
 - Resolution: 0.1 for 0.1 to 99.9, 1 for 100 to 200
 - Unit: s
 - Program data <*test-voltage range*{0|1}>
 - Data format: Integer
 - Set value: 0: AUTO; 1: 5 kV

- Program data *<current-detection response speed{0|1|2}>*
 Data format: Integer
 Set value: 0: SLOW; 1: MID; 2: FAST
- Program data *<GND{GUARD|LOW}>*
 Data format: Character
 Set value: LOW (0), GUARD (1)
- Program data *<contact check{ON|OFF}>*
 Data format: Character
 Set value: OFF, ON (0, 1)
- Program data *<scanner Hi/Low>*
 Data format: Integer
 Set value: 0 to 65535 (#HFFFF)
 Resolution: 1
 LOW is represented by 0 and HIGH by 1.
- Program data *<scanner Open>*
 Data format: Integer
 Set value: 0 to 65535 (#HFFFF)
 Resolution: 1
 OPEN is represented by 1 and NOT OPEN by 0.
 OPEN has priority over HIGH/LOW.

Response message

To A:MEM? *<memory number>*, the contents of memory specified by memory number are returned.

The memory contents are returned in the same order as with program messages.

(Example) If memory 10, at inquiry, contains the memory name ACW10, test voltage of 5.00 kV, lower current of 5.00 mA, upper current of 80.0 mA, test time of 2.0 s, frequency of 50 Hz, lower judgment set to ON, offset set to OFF, timer set to ON, start voltage of 15%, voltage rise time of 0.2 s, voltage fall time of 0.4 s, voltage range of AUTO, current-detection response speed of SLOW, GND set to LOW, contact check set to ON, scanners 1 through 5 set to Low, scanners 6 through 10 set to High, and the other scanners set to Open, then,

“ACW10,5.00E3,5.00E-3,80.0E-3,2.0,50,1,0,1,15,0.2,0.4,0,0,0,1,992,64512” is returned.

DCW:MEMORY (D:MEM)

Stores the test conditions for a DC withstanding voltage test to a specified memory number. Also inquires about the contents of the memory with the specified number.

Program message

- Syntax

Command message: DCW:MEMORY (D: MEM) <memory number, "memory name", test voltage, lower current, upper current, test time, lower judgment{ON|OFF}, timer{ON|OFF}, start voltage, voltage rise time, WAIT TIME, GND{GUARD|LOW}, contact check{ON|OFF}, scanner Hi/Low, scanner Open>

Query message: DCW:MEMORY?
D:MEM?

- Program data <memory number>

Data format: Integer

Set value: 0 to 99

Resolution: 1

- Program data <memory name>

Data format: String

Set value: ASCII Code 20H to 7EH (up to 12 characters)
(Except 22H ("), 27H ('), 2CH (,), 3BH (;), and 40H (@))
Put Set value in 22Hs (".)

- Program data <test voltage>

Data format: Real number

Set value: 0.00 to 6.00 E3

Resolution: 0.01 E3

Unit: V

- Program data <lower current>

Data format: Real number

Set value: 0.01 E-3 to 11.0 E-3

Resolution: 0.01 for 0.01 E3 to 9.99 E-3, 0.1 for 10.0 E-3 to 11.0 E-3

Unit: A

- Program data <upper current>

Data format: Real number

Set value: 0.01 E-3 to 11.0 E-3

Resolution: 0.01 for 0.01 E3 to 9.99 E-3, 0.1 for 10.0 E-3 to 11.0 E-3

Unit: A

- Program data <*test time*>
 - Data format: Real number
 - Set value: 0.3 to 999
 - Resolution: 0.1 for 0.3 to 99.9, 1 for 100 to 999
 - Unit: s
- Program data <*lower judgment*{ON|OFF}>
 - Data format: Character
 - Set value: OFF, ON (0, 1)
- Program data <*timer*{ON|OFF}>
 - Data format: Character
 - Set value: OFF, ON (0, 1)
- Program data <*start voltage*>
 - Data format: Integer
 - Set value: 0 to 99
 - Resolution: 1
 - Unit: %
- Program data <*voltage rise time*>
 - Data format: Real number
 - Set value: 0.1 to 200
 - Resolution: 0.1 for 0.1 to 99.9, 1 for 100 to 200
 - Unit: s
- Program data <*WAIT TIME*>
 - Data format: Real number
 - Set value: 0.3 to 10.0
 - Resolution: 0.1
 - Unit: s
- Program data <*GND*{GUARD|LOW}>
 - Data format: Character
 - Set value: LOW (0), GUARD (1)
- Program data <*contact check*{ON|OFF}>
 - Data format: Character
 - Set value: OFF, ON (0, 1)
- Program data <*scanner Hi/Low*>
 - Data format: Integer
 - Set value: 0 to 65535 (#HFFFF)
 - Resolution: 1
 - LOW is represented by 0 and HIGH by 1.

- Program data <*scanner Open*>
 - Data format: Integer
 - Set value: 0 to 65535 (#HFFFF)
 - Resolution: 1
 - OPEN is represented by 1 and NOT OPEN by 0.
 - OPEN has priority over HIGH/LOW.

Response message

To D:MEM? _<*memory number*>, the contents of the memory specified by memory number are returned. The memory contents are returned in the same order as with program messages.

(Example) If memory 12, at inquiry, contains the memory name DCW12, test voltage of 5.50 kV, lower current of 5.00 mA, upper current of 10.0 mA, test time of 2.0 s., lower judgment set to ON, timer set to ON, start voltage of 20%, voltage rise time of 0.2 s, WAIT TIME of 0.5 s, GND set to LOW, contact check set to ON, scanners 1 through 5 set to Low, scanners 6 through 10 set to High, and the other scanners set to Open, then, "DCW12,5.50E3,5.00E-3,10.0E-3,2.0,1,1,20,0.2,0.5,0,1,992,64512" is returned.

IR:MEMORY (I:MEM)

Stores the test conditions for an insulation resistance test to a specified memory number. Also inquires about the contents of the memory with the specified number.

Program message

- Syntax
 - Command message: IR:MEMORY (I:MEM)_<*memory number*,
"memory name", *test voltage*, *lower resistance*,
upper resistance, *test time*, *lower judgment*
{ON|OFF}, *upper judgment*{ON|OFF}, *timer*{ON|OFF},
voltage rise time, *WAIT TIME*, *GND*{GUARD|LOW},
contact check{ON|OFF}, *scanner Hi/Low*, *scanner*
Open>
 - Query message: IR:MEMORY?
I:MEM?
- Program data <*memory number*>
 - Data format: Integer
 - Set value: 0 to 99
 - Resolution: 1

- Program data <*memory name*>
 - Data format: String
 - Set value: ASCII Code 20H to 7EH (up to 12 characters)
(Except 22H ("), 27H ('), 2CH (,), 3BH (;), and 40H (@))
Put Set value in 22H (".)
- Program data <*test voltage*>
 - Data format: Real number
 - Set value: 10 to 1020
 - Resolution: 1
 - Unit: V
- Program data <*lower resistance*>
 - Data format: Real number
 - Set value: 0.01 E6 to 9.99 E9
 - Resolution: 0.01 E6 (0.01 E6 to 9.99 E6)
0.1 E6 (10.0 E6 to 99.9 E6)
1 E6 (100 E6 to 999 E6)
0.01 E9 (1.00 E9 to 9.99 E9)
 - Unit: Ω
- Program data <*upper resistance*>
 - Data format: Real number
 - Set value: 0.01 E6 to 9.99 E9
 - Resolution: 0.01 E6 (0.01 E6 to 9.99 E6)
0.1 E6 (10.0 E6 to 99.9 E6)
1 E6 (100 E6 to 999 E6)
0.01 E9 (1.00 E9 to 9.99 E9)
 - Unit: Ω
- Program data <*test time*>
 - Data format: Real number
 - Set value: 0.5 to 999
 - Resolution: 0.1 for 0.5 to 99.9, 1 for 100 to 999
 - Unit: s
- Program data <*lower judgment*{ON|OFF}>
 - Data format: Character
 - Set value: OFF, ON (0, 1)
- Program data <*upper judgment*{ON|OFF}>
 - Data format: Character
 - Set value: OFF, ON (0, 1)
- Program data <*timer*{ON|OFF}>
 - Data format: Character
 - Set value: OFF, ON (0, 1)

- Program data <*voltage rise time*>
 - Data format: Real number
 - Set value: 0.1 to 200
 - Resolution: 0.1 for 0.1 to 99.9, 1 for 100 to 200
 - Unit: s
- Program data <*WAIT TIME*>
 - Data format: Real number
 - Set value: 0.3 to 10.0
 - Resolution: 0.1
 - Unit: s
- Program data <*GND*{*GUARD* | *LOW*}>
 - Data format: Character
 - Set value: LOW (0), GUARD (1)
- Program data <*contact check*{*ON* | *OFF*}>
 - Data format: Character
 - Set value: OFF, ON (0, 1)
- Program data <*scanner Hi/Low*>
 - Data format: Integer
 - Set value: 0 to 65535 (#HFFFF)
 - Resolution: 1
 - LOW is represented by 0 and HIGH by 1.
- Program data <scanner Open>
 - Data format: Integer
 - Set value: 0 to 65535 (#HFFFF)
 - Resolution: 1
 - OPEN is represented by 1 and NOT OPEN by 0.
 - OPEN has priority over HIGH/LOW.

Response message

To I:MEM? _<*memory number*>, the contents of the memory specified by memory number are returned.

The memory contents are returned in the same order as with program messages.

(Example) If memory 15, at inquiry, contains the memory number IR15, test voltage of 50 V, lower resistance of 0.05 M Ω , upper resistance of 10.0 M Ω , test time of 2.0 s., lower judgment set to ON, upper judgment set to OFF, timer set to ON, voltage rise time of 0.2 s, WAIT TIME of 0.5 s, GND set to LOW, contact check set to ON, scanners 1 through 5 set to Low, scanners 6 through 10 set to High, and the other scanners set to Open, then
 “IR15,50,0.05E6,10.0E6,2.0,1,0,1,0.2,0.5,0,1,992,64512” is returned.

3.8 Program-Related Messages

This section describes the messages used in connection with the program (AUTO).

PRGNAME (PNAM)

Specifies a program number and names the program. Also inquires about the program name.

Program message

- Syntax

Command message: `PRGNAME_<program number>, "program name">`

`PNAM_<program number>, "program name">`

Query message: `PRGNAME?_<program number>`

`PNAM?_<program number>`

- Program data <program number>

Data format: Integer

Set value: 0 to 99

Resolution: 1

- Program data <program name>

Data format: String

Set value: ASCII Code 20H to 7EH (up to 12 characters)
(Except 22H ("), 27H ('), 2CH (,), 3BH (;), and 40H (@))
Put Set value in 22Hs (".)

(Example) To name program 10 "TEST 10,"

`PNAM 10, "TEST 10"`

Response message

To `PNAM?_<program number>`, the name of the program with the specified number is returned.

(Example) If the name of program 10 is TEST10, "TEST10" is returned.

PRGTEST (PTES)

Sets the specified program.

Program message

- Syntax

Command message: PRGTEST_<program number>
PTES_<program number>

- Program data

Data format: Integer

Set value: 0 to 99

Resolution: 1

(Example) To set program 10,

PTES 10

PRGEDIT (PED)

Creates a program using stored memory. Also inquires about the contents of the program corresponding to a program number and step number.

Following execution of this message, the program edit screen automatically appears.

Program message

- Syntax

Command message: PRGEDIT_<program number, step number, mode selection {0|1|2|3}>, memory number, interval time>
PED_<program number, step number, mode selection {0|1|2|3}, memory number, interval time>

Query message: PRGEDIT? (PED?)_<program number, step number>
PED?_<program number, step number>

- Program data <program number>

Data format: Integer

Set value: 0 to 99

Resolution: 1

- Program data <step number>

Data format: Integer

Set value: 0 to 99

Resolution: 1

- Program data *<mode selection {0|1|2|3}>*
 - Data format: Integer
 - Set value: 0: ACW; 1: DCW; 2: IR; 3: EC
- Program data *<memory number>*
 - Data format: Integer
 - Set value: 0 to 99
 - Resolution: 1
- Program data *<interval time>*
 - Data format: Real number, character
 - Set value: 0.2 to 9.9, HOLD
 - Resolution: 0.1
 - Unit: s

NOTE

- All parameters must be entered, even if the value isn't changed.
 - Do not skip a step number. Overwrite the existing step, or add a new step after the last step.
 - Up to 500 steps can be used in a set of programs.
For example, if 100 steps are set for each of programs 0 to 4, no step is available for program 5.
-

(Example) At step 15 of program 10, to program memory 3 for AC withstanding voltage testing at an interval time of 2 s,

PED 10,15,0,3,2.0

Response message

To PED?_<program number, step number>, the contents of the specified step of a specified program are returned.

(Example) If, at step 15 of program 10, memory 3 for AC withstanding voltage testing is programmed at an interval time of 2 s,
“0,3,2” is returned.

PRGRETURN (PRET)

Makes the RETURN/END settings for a specified program.

Also inquires about the RETURN/END setting for a specified program.

Program message

- Syntax

Command message: PRGRETURN_<program number, {ON|OFF}>
PRET_<program number, {ON|OFF}>

Query message: PRGRETURN?_<program number>
PRET?_<program number>

- Program data <program number>

Data format: Integer

Set value: 0 to 99

Resolution: 1

- Program data <program name>

Data format: Character

Set value: OFF (0), ON (1)

(Example) To set program 10 to RETURN,

PRET 10,ON

Response message

To PRET?_<program number>, the RETURN setting for the specified program is returned.

(Example) If program 10 is set to the END mode,
0 is returned.

PRGNEW (PNEW)

Deletes a specified program.

Program message

- Syntax

Command message: PRGNEW_<program number>
PNEW_<program number>

- Program data

Data format: Integer

Set value: 0 to 99

Resolution: 1

(Example) To delete program 10,

PNEW 10

PRGTOTAL (PTOT)

Inquires about the total number of steps in a specified program

Program message

- Syntax
 - Query message: PRGTOTAL?_<program number>
PTOT?_<program number>
- Program data <program number>
 - Data format: Integer
 - Set value: 0 to 99
 - Resolution: 1

Response message

To PRET?_<program number>, the total number of steps in a specified program is returned.

(Example) If the total number of step in program 10 is 55,
55 is returned.

PRGINS (PIN)

Inserts a memory number into the specified step of a specified program. Following the execution of this message, the tester automatically displays the program edit screen.

Program message

- Syntax
 - Command message: PRGINS_<program number, step number, mode selection{0|1|2|3}, memory number>
PIN_<program number, step number, mode selection{0|1|2|3}, memory number>
- Program data <program number>
 - Data format: Integer
 - Set value: 0 to 99
 - Resolution: 1
- Program data <step number>
 - Data format: Integer
 - Set value: 0 to 99
 - Resolution: 1

- Program data *<mode selection {0|1|2|3}>*
 Data format: Integer
 Set value: 0: ACW; 1: DCW; 2: IR; 3: EC
- Program data *<memory number>*
 Data format: Integer
 Set value: 0 to 99
 Resolution: 1

NOTE

- Do not skip a step number. Overwrite the existing step or add a new step after the last step.
 - Up to 500 steps can be used in a set of programs. For example, if 100 steps are set for each of programs 0 to 4, no step is available for program 5.
-

(Example) To insert memory 3 for AC withstanding voltage testing into step 15 of program 10,
 PIN 10,15,0,3

PRGDEL (PDEL)

Deletes the specified step of a specified program

Program message

- Syntax
 Command message: PRGDEL_ *<program number, step number>*
 PDEL_ *<program number, step number>*
- Program data *<program number>*
 Data format: Integer
 Set value: 0 to 99
 Resolution: 1
- Program data *<step number>*
 Data format: Integer
 Set value: 0 to 99
 Resolution: 1

(Example) To delete step 15 from program 10,
 PDEL 10,15

AUTORUNNING (ARUN)

Inquires which step the program is currently executing

Program message

- Syntax

Query message: AUTORUNNING?
 ARUN?

Response message

To ARUN?, the step currently being executed by the program is returned.

(Example) If step 55 of the program is being executed,
55 is returned.

3.9 Registers

Protection register 1
 OVER LOAD: Over 550VA (DCW: 55 W)
 LVP (Low Volt): Over Crrrent
 OCP: Current Sensor
 OHP TIMER: Over Heat Timer (50 mA, 30 min)
 OHP: Over Heat

Protection register 2
 TOS62 PROT: TOS6200 Protection
 TOS62 COMM: TOS6200 Communication Error
 REN: Remote Enable
 REM IO: Remote In/Out
 SCAN: Scanner In/Out
 INTERLOCK: Interlock
 10%±50V: Volt setting
 100/200: Select 100/200




Fig.3-4 Structure of status data

NOTE

- In a command message in each register, hexadecimal data can be used by adding “#H”.
- In a query message in each register, all response data is composed of decimals.
- For each bit of each register, 1 represents “set” and 0 represents “reset.”
- The contents of the enable register are not backed up.

Status Byte register, Service-Request Enable register

Bit		Description
7		Not used with this tester
6	"RQS (Request)"	Confirms that a service request has been issued. Reset by being read by series polling.
	"MSS (Master Summary Status)"	Logical sum of the status byte register and the service-request enable register. Read by *STB?
5	"ESB (Standard Event Status Bit)"	Indicates that a bit of the event status register has been set
4	"DSB (Device Status Bit)"	Indicates that a bit of the device status register has been set
3		Not used with this tester
2		Not used with this tester
1		Not used with this tester
0		Not used with this tester

Table 3-1 Status Byte register and Service-Request Enable register

Event Status register

Bit		Description
7		Not used with this tester
6		Not used with this tester
5	CME (Command Error)	Indicates a syntax error, data error, or our-of-range error
4	EXE (Execution Error)	Indicates that an invalid message has been received during the test or in the protection status
3		Not used with this tester
2		Not used with this tester
1		Not used with this tester
0		Not used with this tester

Table 3-2 Event Status register

Device Status register, Device-Status Enable register

Bit	Description
7	PROT (Protection)
6	STOP
5	FAIL
4	PASS
3	HV ON
2	TEST
1	INV SET (Invalid setting)
0	READY

Table 3-3 Device Status register and Device-Status Enable register




Fig.3-5 Relation of TEST (Bit 2) to HV ON (Bit 3).

Protection register 1

Bit	Description
7	Not used with this tester
6	Not used with this tester
5	Not used with this tester
4	OVER LOAD
3	LVP (Low Voltage Protection)
2	OCP (24 V)
1	OHP TIMER (Over Heat Timer)
0	OHP (Over Heat Protection)

Table 3-4 Protection register

Protection register 2

Bit	Description
7	TOS6200 PROT (Protection)
6	TOS6200 COMM (Communication Error)
5	REN (Remote Enable)
4	REM IO (Remote In/Out)
3	SCAN (Scanner In/Out)
2	INTERLOCK
1	10 %±50 V (Setting 10 %±50 V)
0	100/200 (Select 100/200)

Table 3-5 Protection register

Fail register

Bit		Description
7		Not used with this tester
6		Not used with this tester
5		Not used with this tester
4		Not used with this tester
3		Not used with this tester
2	UPPER FAIL	Indicates FAIL for the upper cutoff value
1	LOWER FAIL	Indicates FAIL for the lower cutoff value
0	CONTACT FAIL	Indicates FAIL in a contact check

Table 3-6 Fail register

Invalid-Setting register

Bit		Description
7		Not used with this tester
6		Not used with this tester
5		Not used with this tester
4	SCANNER CHANNEL	When an unconnected channel has been specified
3	WAIT TIME	At rise time + test time \leq wait time
2	UP \leq LOW	When the lower cutoff value exceeds the upper cutoff value
1	OVER 1.1mA	In IR, when the test voltage divided by the lower resistance has exceeded 1.1 mA
0	OVER 550VA	In ACW, when the test voltage multiplied by the upper current has exceeded 550 VA (55 W in DCW)

Table 3-7 Invalid-Setting register

Error register

Bit		Description
7		Not used with this tester
6		Not used with this tester
5		Not used with this tester
4		Not used with this tester
3	Invalid message	Indicates an invalid message
2	Out-of-range error	Indicates an out-of-range error
1	Data Error	Indicates a data error
0	Syntax Error	Indicates a header error

Table 3-8 Error register

3.10 Message List

The symbols in parentheses in the Header column represent abbreviated messages. R/W represents a query message (R) or command message (W).

Note 1: The commands that are valid during a rise time, test time, fall time, pass judgment, fail judgment, or interval time are marked with “①”, and invalid commands are indicated by “②”. The commands valid only in the ready status or interval hold status are marked with “③”.

Note 2: The commands valid in the protection status are marked with “①”, and the invalid commands are marked with “②”.

3.10.1 Register-related messages and general messages

	Header	Data					Function and response data	A	B
		R/W	Min.	Max.	Resolution	Unit		Note 1	Note 2
1	*RST	W				--	Initializes devices. (Resets to factory settings, except for the INTERFACE screen settings)	①	①
2	*IDN?	R				--	Returns “KIKUSUI ELECTRONICS CORP., TOS9200, 0, x.xx” (TOS9200).	①	①
3	ERR?	R				--	Returns an error value and clears it.	①	①
4	TRM	W	0	3		--	Sets the terminator. 0: CR LF+EOI; 1: LF+EOI; 2: EOI; 3: CR+EOI	②	②
5	TRM?	R				--	Returns the preset terminator value.	①	①
6	*CLS	W				--	Clears the status byte register, event status register, device status register, protection register 1, protection register 2, fail register, invalid-setting register, and error register.	①	①
7	*STB?	R				--	Returns the status-byte-register value.	①	①
8	*SRE	W	0	255		--	Sets the service-request enable register.	②	②
9	*SRE?	R				--	Returns the service-request-enable-register value.	①	①
10	*ESR?	R				--	Returns the event-status-register value and clears it.	①	①
11	DSE	W	0	255		--	Sets the device-status enable register.	②	②
12	DSE?	R				--	Returns the device-status-enable-register value.	①	①
13	DSR?	R				--	Returns the device-status-register value.	①	①
14	PROTECTION? (PROT?)	R				--	Returns the values of protection registers 1 and 2.	①	①
15	FAIL?	R				--	Returns the fail-register value.	①	①
16	INVALID? (INV?)	R				--	Returns the invalid-setting-register value.	①	①
17	CLR	W				--	Clears all registers and sets a Stop flag (same as DCL and SDC).	①	①
18	SILENT (SIL)	W	0	1	0/1	--	Acknowledge message (RS-232C)	②	②
19	SILENT? (SIL?)	R				--	Returns the acknowledge-message (RS-232C) value.	①	①
20	START (STAR)	W				--	Starts a test. (valid in the ready status and the interval hold status)	③	②
21	STOP	W				--	Suspends the test and cancels the protection status.	①	①
22	FUNCTION (FUN)	W	0	7	1	--	Shifts between modes. 0: ACW; 1: DCW; 2: IR; 3: AUTO TEST; 4: AUTO EDIT; 5: SYSTEM; 6: OFFSET ADJ; 7: INTERFACE	②	②
23	FUNCTION? (FUN?)	R				--	Returns the current mode. 0: ACW; 1: DCW; 2: IR; 3: AUTO TEST; 4: AUTO EDIT; 5: SYSTEM; 6: OFFSET ADJ; 7: INTERFACE	①	①
24	LOCAL (LOC)	W				--	Return to the LOCAL from the REMOTE state.	②	①

3.10.2 Messages for AC withstanding voltage testing

	Header	Data					Function and response data	A	B
		R/W	Min.	Max.	Resolution	Unit		Note 1	Note 2
25	ACW:TESTV (A:TES)	W	0.00	5.20 E3	0.01 E3	V	Sets the test voltage.	①	②
26	ACW:TESTV? (A:TES?)	R	0.00 E3	5.20 E3		V	Returns the test-voltage setting.	①	①
27	ACW:FREQUENCY (A:FREQ)	W	50	60	50/60	Hz	Sets the output frequency.	②	②
28	ACW:FREQUENCY? (A:FREQ?)	R				Hz	Returns the output-frequency setting.	①	①
29	ACW:LOWER (A:LOW)	W	0.01 E-3	110 E-3	0.01, 0.1, 1	A	Lower current (0.01 to 9.99/10.0 to 99.9/100 to 110)	②	②
			OFF	ON	OFF/ON	--	Turns ON/OFF the low judgment function.		
30	ACW:LOWER? (A:LOW?)	R				A, --	Returns the lower current and the ON/OFF status of the judgment function. Returns ON/OFF as 1 or 0.	①	①
31	ACW:UPPER (A:UPP)	W	0.01 E-3	110 E-3	0.01, 0.1, 1	A	Upper current (0.01 to 9.99/10.0 to 99.9/100 to 110)	②	②
32	ACW:UPPER? (A:UPP?)	R				A	Returns the upper current.	①	①
33	ACW:TIMER (A:TIM)	W	0.3	999	0.1, 1	s	Timer set value (0.3 to 99.9/100 to 999)	②	②
			OFF	ON	0/1	--	Timer function		
34	ACW:TIMER? (A:TIM?)	R				s, --	Returns the timer ON/OFF setting. Returns ON/OFF as 1 or 0.	①	①
35	ACW:OFFSET (A:OFF)	W	OFF	ON	0/1	--	Offset function.	②	②
36	ACW:OFFSET? (A:OFF?)	R				--	Returns the ON/OFF status of the offset function Returns ON/OFF as 1 or 0.	①	①
37	ACW:STARTV (A:STAR)	W	0	99	1	%	Sets the start voltage.	②	②
38	ACW:STARTV? (A:STAR?)	R				%	Returns the start-voltage setting.	①	①
39	ACW:RISETIME (A:RTIM)	W	0.1	200	0.1, 1	s	Sets the voltage rise time (0.1 to 99.9/100 to 200).	②	②
40	ACW:RISETIME? (A:RTIM?)	R				s	Returns the voltage-rise-time setting.	①	①
41	ACW:FALLTIME (A:FTIM)	W	0	200	0.1, 1	s	Sets the voltage fall time (0.1 to 99.9/100 to 200).	②	②
42	ACW:FALLTIME? (A:FTIM?)	R				s	Returns the voltage-fall-time setting.	①	①
43	ACW:VRANGE (A:VRAN)	W	0	1	0/1	--	Sets VRANGE (0: AUTO; 1: 5 kV).	②	②
44	ACW:VRANGE? (A:VRAN?)	R	0	1	0/1	--	Returns the VRANGE setting (0: AUTO; 1: 5 kV).	①	①
45	ACW:RESPONSE (A:RES)	W	0	2	0/1/2	--	Sets the response filter (0: SLOW; 1: MID; 2: FAST).	②	②
46	ACW:RESPONSE? (A:RES?)	R				--	Returns the response-filter setting. (0: SLOW; 1: MID; 2: FAST)	①	①
47	ACW:GND (A:GND)	W	LOW	GUARD	0/1	--	1 to set GND to GUARD, and 0 to set to LOW.	②	②
48	ACW:GND? (A:GND?)	R				--	Returns the GUARD/LOW setting for GND as 1 or 0.	①	①
49	ACW:SCAN (A:SCAN)	W	1	16	1	--	Sets channels 1 through 16 to Hi/Low/Open (0: Open; 1: Low; 2: High).	②	②
			O	H	H/L/O	--			
50	ACW:SCAN? (A:SCAN?)	R	1	16	1	--	Returns the Hi/Low/Open setting for channels 1 through 16 (0: Open; 1: Low; 2: High).	①	①
51	ACW:SCANW (A:SCANW)	W	0	65535 #HFFFF	1	--	The 1st data represents channels 1 through 16 with 0: Low and 1: Hi, using 16 bits. The 2nd data represents Open and Not Open, with 1 for Open.	②	②
			0	65535 #HFFFF	1	--			

	Header	Data					Function and response data	A	B
		R/W	Min.	Max.	Resolution	Unit		Note 1	Note 2
52	ACW:SCANW? (A:SCANW?)	R				--	Returns a WORD-type value for Hi/Low and Open/Not Open.	①	①
53	ACW:CONTACT CHECK (A:CCH)	W	OFF	ON	0/1	--	Sets ON/OFF for the scanner contact check function.	②	②
54	ACW:CONTACT CHECK?(A:CCH?)	R	0	1	0/1	--	Returns the ON/OFF status of the scanner contact check function.	①	①

3.10.3 Messages for DC withstanding voltage testing

	Header	Data					Function and response data	A	B
		R/W	Min.	Max.	Resolution	Unit		Note 1	Note 2
55	DCW:TESTV (D:TES)	W	0.00	6.00 E3	0.01 E3	V	Sets the test voltage.	①	②
56	DCW:TESTV? (D:TES?)	R	0.00 E3	6.00 E3		V	Returns the test-voltage setting.	①	①
57	DCW:LOWER (D:LOW)	W	0.01 E-3	11.0 E-3	0.01,0.1	A	Lower current (0.01 to 9.99/10.0 to 11.0)	②	②
			OFF	ON	OFF/ON	--	Turns the low judgment function ON/OFF.		
58	DCW:LOWER? (D:LOW?)	R				A, --	Returns the lower current and the ON/OFF status of the judgment function. Returns ON/OFF as 1 or 0.	①	①
59	DCW:UPPER (D:UPP)	W	0.01 E-3	11.0 E-3	0.01,0.1	A	Upper current (0.01 to 9.99/10.0 to 11.0)	②	②
60	DCW:UPPER? (D:UPP?)	R				A	Returns the upper current.	①	①
61	DCW:TIMER (D:TIM)	W	0.1	999	0.1, 1	s	Timer set value (0.3 to 99.9/100 to 999)	②	②
			OFF	ON	0/1	--	Timer function		
62	DCW:TIMER? (D:TIM?)	R				s, --	Returns the timer ON/OFF setting. Returns ON/OFF as 1 or 0.	①	①
63	DCW:STARTV (D:STAR)	W	0	99	1	%	Sets the start voltage.	②	②
64	DCW:STARTV? (D:STAR?)	R				%	Returns the start-voltage setting.	①	①
65	DCW:RISETIME (D:RTIM)	W	0.1	200	0.1, 1	s	Sets the voltage rise time (0.1 to 99.9/100 to 200)	②	②
66	DCW:RISETIME? (D:RTIM?)	R				s	Returns the voltage-rise-time setting.	①	①
67	DCW:WAITTIME (D:WTIM)	W	0.3	10	0.1	s	Sets the WAIT TIME (0.3 to 10.0)	②	②
68	DCW:WAITTIME? (D:WTIM?)	R				s	Returns the judgment-wait-time setting.	①	①
69	DCW:GND(D:GND)	W	LOW	GUARD	0/1	--	1 to set GND to GUARD, and 0 to set to LOW	②	②
70	DCW:GND? (D:GND?)	R				--	Returns the GUARD/LOW setting for GND as 1 or 0.	①	①
71	DCW:SCAN (D:SCAN)	W	1	16	1	--	Sets channels 1 through 16 to Hi/Low/Open (0: Open; 1: Low; 2: High).	②	②
			H	L	H/L/O	--			
72	DCW:SCAN? (D:SCAN?)	R	1	16	1	--	Returns the Hi/Low/Open setting for channels 1 through 16 (0: Open; 1: Low; 2: High).	①	①
73	DCW:SCANW (D:SCANW)	W	0	65535 #HFFFF	1	--	The 1st data represents channels 1 through 16 with 0: Low and 1: Hi, using 16 bits. The 2nd data represents Open and Not Open, with 1 for Open. The Open setting for the 2nd data has priority over the 1st data.	②	②
			0	65535 #HFFFF	1	--			
74	DCW:SCANW? (D:SCANW?)	R				--	Returns a WORD-type value for Hi/Low and Open/Not Open.	①	①

	Header	Data					Function and response data	A	B
		R/W	Min.	Max.	Resolution	Unit		Note 1	Note 2
75	DCW:CONTACT CHECK (D:CCH)	W	OFF	ON	0/1	--	Sets ON/OFF of the scanner contact check function.	②	②
76	DCW:CONTACT CHECK? (D:CCH?)	R	0	1	0/1	--	Returns the ON/OFF status of the scanner contact check function.	①	①

3.10.4 Messages for insulation resistance testing

	Header	Data					Function and response data	A	B
		R/W	Min.	Max.	Resolution	Unit		Note 1	Note 2
77	IR:TESTV (I:TES)	W	10	1020	1	V	Sets the test voltage.	①	②
78	IR:TESTV? (I:TES?)	R				V	Returns the test-voltage setting.	①	①
79	IR:LOWER (I:LOW)	W	0.01 E6	9.99 E9	0.01	Ω	Lower resistance (0.01 M to 9.99 M, 10.0 M to 99.9 M, 100 M to 999 M, 1.00 G to 9.99 G)	②	②
			OFF	ON					
80	IR:LOWER? (I:LOW?)	R				Ω	Returns the lower resistance. Uses M Ω as the unit. Returns the ON/OFF status of the judgment function. Returns ON/OFF as 1 or 0.	①	①
81	IR:UPPER (I:UPP)	W	0.01 E6	9.99 E9	0.01	Ω	Upper resistance (0.01 M to 9.99 M, 10.0 M to 99.9 M, 100 M to 999 M, 1.00 G to 9.99 G)	②	②
			OFF	ON					
82	IR:UPPER? (I:UPP?)	R				Ω --	Returns the upper resistance (in M Ω) and the ON/OFF status of the upper judgment function. Returns ON/OFF as 1 or 0.	①	①
83	IR:TIMER (I:TIM)	W	0.5	999	0.1, 1	s	Timer set value (0.5 to 99.9/100 to 999)	②	②
			OFF	ON	0/1	--	Timer function		
84	IR:TIMER? (I:TIM?)	R				s, --	Returns the timer value and the ON/OFF status of the timer. Returns ON/OFF as 1 or 0.	①	①
85	IR:RISETIME (I:RTIM)	W	0.1	200	0.1, 1	s	Sets the voltage rise time (0.1 to 99.9/100 to 200).	②	②
86	IR:RISETIME? (I:RTIM?)	R				s	Returns the voltage-rise-time setting.	①	①
87	IR:WAITTIME (I:WTIM)	W	0.3	10	0.1	s	Sets the WAIT TIME (0.3 to 10.0).	②	②
88	IR:WAITTIME? (I:WTIM?)	R				s	Returns the judgment-wait-time setting.	①	①
89	IR:GND (I:GND)	W	LOW	GUARD	0/1	--	1 to set GND to GUARD, and 0 to set it to LOW	②	②
90	IR:GND? (I:GND?)	R				--	Returns the GUARD/LOW setting for GND as 1 or 0.	①	①
91	IR:SCAN (I:SCAN)	W	1	16	1	--	Sets channels 1 through 16 to Hi/Low/Open.	②	②
			H	L	H/L/O	--			
92	IR:SCAN? (I:SCAN?)	R	1	16	1	--	Returns the Hi/Low/Open settings for channels 1 through 16.	①	①
93	IR:SCANW (I:SCANW)	W	0	65535 #HFFFF	1	--	The 1st data represents channels 1 through 16 with 0: Low and 1: Hi, using 16 bits. The 2nd data represents Open and Not Open, with 1 for Open. The Open setting for the 2nd data has priority over the 1st data.	②	②
			0	65535 #HFFFF	1	--			
94	IR:SCANW? (I:SCANW?)	R				--	Returns a WORD-type value for Hi/Low and Open/Not Open.	①	①
95	IR:CONTACT CHECK (I:CCH)	W	OFF	ON	0/1	--	Sets ON/OFF for the scanner contact check function.	②	②
96	IR:CONTACT CHECK?(I:CCH?)	R	0	1	0/1	--	Returns the ON/OFF status of the scanner contact check function.	①	①

3.10.5 Messages common to all tests

	Header	Data					Function and response data	A	B
		R/W	Min.	Max.	Resolution	Unit		Note 1	Note 2
97	VDATA? (VDAT?)	R				V	Monitor voltage (ACW: 0 E3 to 9.99 E3) (DCW: 0 E3 to 99.9 E3) (IR: 0 to 9999)	①	①
98	IDATA? (IDAT?)	R				A	Monitor current (ACW: 0 to 999 E-6, 1.00 E-3 to 9.99 E-3, 10.0 E-3 to 99.9 E-3, 100 E-3 to 999 E-3) (DCW: 0 to 999 E-6, 1.00 E-3 to 9.99 E-3, 10.0 E-3 to 99.9 E-3)	①	①
99	RDATA? (RDAT?)	R				Ω	Monitor resistance (0.01 E6 to 9.99 E6, 10.0 E6 to 99.9 E6, 100 E6 to 999 E6, 1.00 E9 to 9.99 E9)	①	①
100	REALDATA? (REAL?)	R				A	Real current (0 to 999 E-6, 1.00 E-3 to 9.99 E-3, 10.0 E-3 to 99.9 E-3, 100 E-3 to 999 E-3)	①	①
101	IMAGDATA? (IMAG?)	R				A	Imaginary current (0 to 999 E-6, 1.00 E-3 to 9.99 E-3, 10.0 E-3 to 99.9 E-3, 100 E-3 to 999 E-3)	①	①
102	TIME?	R				s, --	Returns the elapsed (remaining) time (0 s to 99.9 s, 100 s to 999 s) and Rise/Test/Fall/End (0/1/2/3). Returns the elapsed time when the timer is off. Returns the remaining time when the timer is on.	①	①
103	MON?	R					Test type (0: ACW; 1: DCW; 2: IR) Monitor voltage (W: 0 E3 to 99.9 E3; IR: 0 to 9999) Monitor current Norm (0 to 999 E-6, 1.00 E-3 to 9.99 E-3, 10.0 E-3 to 99.9 E-3, 100 E-3 to 999 E-3) Monitor current MAX (0 to 999 E-6, 1.00 E-3 to 9.99 E-3, 10.0 E-3 to 99.9 E-3, 100 E-3 to 999 E-3) Monitor resistance Norm (0.01 E6 to 9.99 E6, 10.0 E6 to 99.9 E6, 100 E6 to 999 E6, 1.00 E9 to 9.99 E9) Monitor resistance Min (0.01 E6 to 9.99 E6, 10.0 E6 to 99.9 E6, 100 E6 to 999 E6, 1.00 E9 to 9.99 E9) Real current (0 to 999 E-6, 1.00 E-3 to 9.99 E-3, 10.0 E-3 to 99.9 E-3, 100 E-3 to 999 E-3) Imaginary current (0 to 999 E-6, 1.00 E-3 to 9.99 E-3, 10.0 E-3 to 99.9 E-3, 100 E-3 to 999 E-3) Monitor current IR (0 to 999 E-9, 1.00 E-6 to 9.99 E-6, 100 E-6 to 999 E-6, 1.00 E-3 to 9.99 E-3, 10.0 E-3 to 99.9 E-3, 100 E-3 to 999 E-3) Monitor resistance DCW (0.01 E6 to 9.99 E6, 10.0 E6 to 99.9 E6, 100 E6 to 999 E6, 1.00 E9 to 9.99 E9, 10.0 E9 to 99.9 E9, 100 E9 to 999 E9) Elapsed (remaining) time (0 s to 99.9 s, 100 s to 999 s) Separates Rise/Test/Fall/End (0/1/2/3) using “;” in this order and then returns it. The results of the previous test are returned except during the test. Returns the monitor current in ACW and DCW, and the monitor resistance in IR.	①	①
104	SCANTYPE? (STYP?)	R				--	Returns the number of valid channels and the scanner type (Units 1 through 4). (0: none; 1: TOS9220; 2: TOS9221)	①	①
105	CFAILCH? (CFCH?)	R				--	Returns the channel number (1 through 16) in the CONTACT FAIL status.	①	①

3.10.6 System-related messages

	Header	Data					Function and response data	A	B
		R/W	Min.	Max.	Resolution	Unit		Note 1	Note 2
106	MEASMODE (MMOD)	W	NORM	MAX		--	Sets the measured-current (resistance) display mode. NORM: Real Time; MAX: Max Hold	②	②
107	MEASMODE? (MMOD?)	R	0	1	0/1	--	Sets the measured-current (resistance) display mode. 0: Real Time; 1: Max Hold	①	①
108	PASSHOLD (PHOL)	W	0.2	10 HOLD	0.1	s	Pass hold time	②	②
109	PASSHOLD? (PHOL?)	R				s	Returns the pass hold time. 0.2 to 10.0 or HOLD	①	①
110	BUZZERVOL (BVOL)	W	0	10	1	--	Sets the buzzer volume.	①	①
111	BUZZERVOL? (BVOL?)	R				--	Returns the buzzer-volume setting.	①	①
112	CONTRAST (CON)	W	0	10	1	--	Sets the contrast level.	①	①
113	CONTRAST? (CON?)	R				--	Returns the contrast setting.	①	①
114	MOMENTARY (MOM)	W	OFF	ON	OFF/ON	--	Start momentary	②	②
115	MOMENTARY? (MOM?)	R				--	Returns the start-momentary setting. ON/OFF is returned as 1 or 0.	①	①
116	FAILMODE (FMOD)	W	OFF	ON	OFF/ON	--	Fail mode (The STOP key used to cancel the Fail and Protection statuses.)	②	②
117	FAILMODE? (FMOD?)	R				--	Returns the Fail-mode value. ON/OFF is returned as 1 or 0.	①	①
118	DOUBLEACTION (DAC)	W	OFF	ON	OFF/ON	--	Start double action	②	②
119	DOUBLEACTION? (DAC?)	R				--	Returns the start-double-action value. ON/OFF is returned as 1 or 0.	①	①
120	SIGHVON (SHV)	W	OFF	ON	OFF/ON	--	Sets the value of Status Signal Output: HVON.	①	①
121	SIGHVON? (SHV?)	R				--	ON/OFF is returned as 1 or 0.	①	①
122	SIGTEST (STES)	W	OFF	ON	OFF/ON	--	Sets the value of Status Signal Output: TEST.	①	①
123	SIGTEST? (STES?)	R				--	ON/OFF is returned as 1 or 0.	①	①
124	SIGPASS (SPAS)	W	OFF	ON	OFF/ON	--	Sets the value of Status Signal Output: PASS.	①	①
125	SIGPASS? (SPAS?)	R				--	ON/OFF is returned as 1 or 0.	①	①
126	SIGUFAIL (SUF)	W	OFF	ON	OFF/ON	--	Sets the value of Status Signal Output: U FAIL.	①	①
127	SIGUFAIL? (SUF?)	R				--	ON/OFF is returned as 1 or 0.	①	①
128	SIGLFAIL (SLF)	W	OFF	ON	OFF/ON	--	Sets the value of Status Signal Output: L FAIL.	①	①
129	SIGLFAIL? (SLF?)	R				--	ON/OFF is returned as 1 or 0.	①	①
130	SIGREADY (SREA)	W	OFF	ON	OFF/ON	--	Sets the value of Status Signal Output: READY.	①	①
131	SIGREADY? (SREA?)	R				--	ON/OFF is returned as 1 or 0.	①	①
132	SIGPROTECTION (SPR)	W	OFF	ON	OFF/ON	--	Sets the value of Status Signal Output: PROTECTION.	①	①
133	SIGPROTECTION? (SPR?)	R				--	ON/OFF is returned as 1 or 0.	①	①
134	SIGCFail (SCF)	W	OFF	ON	OFF/ON	--	Sets the value of Status Signal Output: CONTACT FAIL.	①	①

	Header	Data					Function and response data	A	B
		R/W	Min.	Max.	Resolution	Unit		Note 1	Note 2
135	SIGCFAIL? (SCF?)	R				--	ON/OFF is returned as 1 or 0.	①	①
136	SIGPOWERON (SPOW)	W	OFF	ON	OFF/ON	--	Sets the value of Status Signal Output: POWER ON.	①	①
137	SIGPOWERON? (SPOW?)	R				--	ON/OFF is returned as 1 or 0.	①	①
138	COMMENT (COM)	W	20H	7EH		--	Comment (memo) 20 characters in the 1st line *1	②	②
			20H	7EH		--	Comment (memo) 20 characters in the 2nd line *1		
			20H	7EH		--	Comment (memo) 20 characters in the 3rd line *1		
			(**1: 20H to 7EH are ASCII code. Put Set value in 22Hs (.) Except (*), ('), (.), (:), and (@))						
139	COMMENT? (COM?)	R				--,--, --	Returns a comment (memo). 1st line, 2nd line, 3rd line	①	①

3.10.7 Memory-related messages

	Header	Data					Function and response data	A	B
		R/W	Min.	Max.	Resolution	Unit		Note 1	Note 2
140	ACW:RECALL (A:REC)	W	0	99	1	--	Recalls ACW memory.	②	②
141	DCW:RECALL (D:REC)	W	0	99	1	--	Recalls DCW memory.	②	②
142	IR:RECALL (I:REC)	W	0	99	1	--	Recalls IR memory.	②	②
143	ACW:STORE (A:STOR)	W	0	99	1	--	Stores the current settings in ACW memory (except for the memory name).	②	②
144	DCW:STORE (D:STOR)	W	0	99	1	--	Stores the current settings in DCW memory (except for the memory name).	②	②
145	IR:STORE (I:STOR)	W	0	99	1	--	Stores the current settings in IR memory (except for the memory name).	②	②
146	ACW:MEMORY (A:MEM)	W	0	99	1	--	Stores the next contents in the memory corresponding to an ACW memory number.	②	②
			20H	7EH		--	Memory name: 12 characters (20H to 7EH are ASCII code. Put Set value in 22Hs (.) Except (*), ('), (.), (:), and (@))		
			0	5.2 E3	0.01	V	Test voltage		
			0.01 E-3	110 E-3	0.01, 0.1, 1	A	Lower current		
			0.01 E-3	110 E-3	0.1, 1	A	Upper current		
			0.3	999	0.1, 1	s	Test time		
			50	60	50/60	Hz	Frequency		
			OFF	ON	OFF/ON	--	Lower ON/OFF		
			OFF	ON	OFF/ON	--	Offset ON/OFF		
			OFF	ON	OFF/ON	--	Timer ON/OFF		
			0	99	1	%	Start-voltage/test-voltage ratio		
			0.1	200	0.1, 1	s	Voltage rise time		
			0	200	0.1, 1	s	Voltage fall time		
			0	1	0/1	--	V RANGE (0: AUTO; 1: 5 kV)		
			0	2	0/1/2	--	Response settings (0: SLOW; 1: MID; 2: FAST)		
			0	1	0/1	--	GND (0: LOW; 1: GUARD)		
			0	1	0/1	--	Contact Check		
0	65535	1	--	Scanner Hi/Low (0 to 0xFFFF:16Bit, 0:Low, 1:Hi)					
0	65535	1	--	Scanner Open (0 to 0xFFFF:16Bit, 0:Hi or Low, 1:Open)					

	Header	Data					Function and response data	A	B
		R/W	Min.	Max.	Resolution	Unit		Note 1	Note 2
147	ACW:MEMORY? (A:MEM?)	R	0	99	1	--	Returns the contents of memory corresponding to the ACW memory number (memory name, test voltage, lower current, upper current, test time, frequency, lower ON/OFF, offset ON/OFF, timer ON/OFF, start-voltage/test-voltage ratio, voltage rise time, voltage fall time, V RANGE (0/1), response filter setting (0/1/2), GND, contact check, scanner Hi/Low, scanner Open). ON/OFF is returned as 1 or 0. Scanner Hi/Low and scanner Open are returned in decimal form using 16 bits.	①	①
148	DCW:MEMORY (D:MEM)	W	0	99	1	--	Stores the next contents in the memory corresponding to a DCW memory number.	②	②
			20H	7EH		--	Memory name: 12 characters (20H to 7EH are ASCII code. Put Set value in 22Hs (".) Except ("), ('), (.), (;), and (@))		
			0	6 E3	0.01	V	Test voltage		
			0.01 E-3	11 E-3	0.01,0.1	A	Lower current		
			0.01 E-3	11 E-3	0.01,0.1	A	Upper current		
			0.3	999	0.1, 1	s	Test time		
			OFF	ON	OFF/ON	--	Lower ON/OFF		
			OFF	ON	OFF/ON	--	Timer ON/OFF		
			0	99	1	%	Start-voltage/test-voltage ratio		
			0.1	200	0.1, 1	s	Voltage rise time		
			0.3	10	0.1	s	WAIT TIME		
			0	1	0/1	--	GND (0: LOW; 1: GUARD)		
0	1	0/1	--	Contact Check					
0	65535	1	--	Scanner Hi/Low (0 to 0xFFFF:16Bit, 0:Low, 1:Hi)					
0	65535	1	--	"Scanner Open (0 to 0xFFFF:16Bit, 0:Hi or Low, 1:Open)"					
149	DCW:MEMORY? (D:MEM?)	R	0	99	1	--	Returns the contents of memory corresponding to the DCW memory number (memory name, test voltage, lower current, upper current, test time, lower ON/OFF, timer ON/OFF, start-voltage/test-voltage ratio, voltage rise time, WAIT TIME, response filter setting (0/1/2), GND, contact check, scanner Hi/Low, scanner Open). ON/OFF is returned as 1 or 0. Scanner Hi/Low and scanner Open are returned in decimal form using 16 bits.	①	①
150	IR:MEMORY (I:MEM)	W	0	99	1	--	Stores the next contents in the memory corresponding to an IR memory number.	②	②
			20H	7EH		--	Memory name: 12 characters (20H to 7EH are ASCII code. Put Set value in 22Hs (".) Except ("), ('), (.), (;), and (@))		
			10	1020	1	V	Test voltage		
			0.01 E6	9.99G E9	0.01, 0.1, 1	Ω ,	Lower current		
			0.01 E6	9.99 E9	0.1, 1	Ω	Upper current		
			0.5	999	0.1, 1	s	Test time		
			OFF	ON	OFF/ON	--	Lower ON/OFF		
			OFF	ON	OFF/ON	--	Timer ON/OFF		
			OFF	ON	OFF/ON	--	Start-voltage/test-voltage ratio		
			0.1	200	0.1, 1	s	Voltage rise time		
			0.3	10	0.1	s	WAIT TIME		
			0	1	0/1	--	GND (0: LOW; 1: GUARD)		
0	1	0/1	--	Contact Check					
0	65535	1	--	Scanner Hi/Low (0 to 0xFFFF:16Bit, 0:Low, 1:Hi)					
0	65535	1	--	"Scanner Open (0 to 0xFFFF:16Bit, 0:Hi or Low, 1:Open)"					

	Header	Data					Function and response data	A	B
		R/W	Min.	Max.	Resolution	Unit		Note 1	Note 2
151	IR:MEMORY? (I:MEM?)	R	0	99	1	--	Returns the contents of the memory corresponding to an IR memory number (memory name, test voltage, lower resistance, upper resistance, test time, upper ON/OFF, timer ON/OFF, voltage rise time, WAIT TIME, GND, contact check, scanner Hi/Low, scanner Open). ON/OFF is returned as 1 or 0. Scanner Hi/Low and scanner Open are returned in decimal form using 16 bits.	①	①

3.10.8 Program-related messages

	Header	Data					Function and response data	A	B
		R/W	Min.	Max.	Resolution	Unit		Note 1	Note 2
152	PRGNAME (PNAM)	W	0	99	1	--	Program number	②	②
			20H	7EH		--	Program name: 12 characters (20H to 7EH are ASCII code. Put Set value in 22Hs (".) Except ("), ('), (,), (:), and (@))		
153	PRGNAME? (PNAM?)	R	0	99	1		Returns the program name corresponding to a program number	①	①
154	PRGTEST (PTES)	W	0	99	1	--	Sets the program corresponding to a program number.	②	②
155	PRGEDIT (PED) Note 3	W	0	99	1	--	Program number	②	②
			0	99	1	--	Program step number		
			0	3	1	--	0: ACW, 1: DCW, 2: IR, 3: EC		
			0	99	1	--	Memory number		
156	PRGEDIT? (PED?)	R	0	99	1	--	Interval time	①	①
			0.2	9.9, HOLD	0.1	s	Proceeds to the next step by pressing the START key when in the HOLD status.		
157	PRGRETURN (PRET)	W	0	99	1	--	Returns the contents of a program corresponding to a program number and step number.	②	②
			OFF	ON	OFF/ON	--	Program number OFF: END (Ends the program) ON: RET (Returns to the first step)		
158	PRGRETURN? (PRET?)	R	0	99	1	--	Returns ON/OFF of the RETURN setting for the program corresponding to a program number.	①	①
159	PRGNEW (PNEW)	W	0	99	1	--	Clears the program corresponding to a program number.	②	②
160	PRGTOTAL? (PTOT?)	R	0	99	1	--	Returns the total number of steps in the program corresponding to a program number.	①	①
161	PRGINS (PIN) Note3	W	0	99	1	--	Program number	②	②
			0	99	1	--	Program step number		
			0	3	1	--	0: ACW, 1: DCW, 2: IR, 3: EC		
			0	99	1	--	Memory number		
162	PRGDEL (PDEL)	W	0	99	1	--	Program number	②	②
			0	99	1	--	Program step number		
163	AUTORUNNING? (ARUN?)	R					Returns the step currently being executed by a program.	①	①

Note 3: When PRGEDIT (PED) or PRGINS (PIN) is executed, the program EDIT screen automatically appears.

Index

Symbols

*CLS 3-1
*ESR 3-2
*IDN 3-2
*RST 3-2
*SRE 3-3
*STB 3-3

A

acknowledge message 2-4, 3-7
ACW:CONTACTCHECK (A:CCH) 3-19
ACW:FALLTIME (A:FTIM) 3-14
ACW:FREQUENCY (A:FREQ) 3-10
ACW:GND (A:GND) 3-16
ACW:LOWER (A:LOW) 3-10
ACW:MEMORY (A:MEM) 3-55
ACW:OFFSET (A:OFF) 3-13
ACW:RECALL (A:REC) 3-52
ACW:RESPONSE (A:RES) 3-15
ACW:RISETIME (A:RTIM) 3-14
ACW:SCAN (A:SCAN) 3-17
ACW:SCANW (A:SCANW) 3-18
ACW:STARTV (A:STAR) 3-13
ACW:STORE (A:STOR) 3-53
ACW:TESTV (A:TES) 3-9
ACW:TIMER (A:TIM) 3-12
ACW:UPPER (A:UPP) 3-11
ACW:VRANGE (A:VRAN) 3-15
all registers 3-4
AUTORUNNING (ARUN) 3-69

B

buzzer volume 3-43
BUZZERVOL (BVOL) 3-43

C

C FAIL 3-42, 3-50
CFAILCH (CFCH) 3-42

CLR 3-4
comment 3-51
COMMENT (COM) 3-51
communication speed 1-3
contrast 3-44
CONTRAST (CON) 3-44
current detection response speed 3-15

D

data length 1-3
DCW:CONTACTCHECK (D:CCH) 3-28
DCW:GND (D:GND) 3-25
DCW:LOWER (D:LOW) 3-21
DCW:MEMORY (D:MEM) 3-58
DCW:RECALL (D:REC) 3-52
DCW:RISETIME (D:RTIM) 3-24
DCW:SCAN (D:SCAN) 3-26
DCW:SCANW (D:SCANW) 3-27
DCW:STARTV (D:STAR) 3-23
DCW:STORE (D:STOR) 3-54
DCW:TESTV (D:TES) 3-20
DCW:TIMER (D:TIM) 3-22
DCW:UPPER (D:UPP) 3-22
DCW:WAITTIME (D:WTIM) 3-24
delete a specified program 3-66
deletes the specified step 3-68
device status register 3-4, 3-72
device-status enable register 3-4, 3-72
DOUBLE ACTION 3-45
DOUBLE ACTION (DAC) 3-45
DSE 3-4
DSR 3-4

E

each monitor value 3-40
ERR 3-5
error register 3-5, 3-73
event status register 3-2, 3-71

F

FAIL 3-5
FAIL MODE 3-45
FAIL MODE (FMOD) 3-45
fail register 3-5, 3-73
FUNCTION (FUN) 3-5

G

GPIB address 1-2
GPIB cable 1-2, 2-1

H

H.V ON 3-46
HIGH/LOW/OPEN for 16 channels 3-27
HIGH/LOW/OPEN for 16 scanner channels
3-18, 3-36
HIGH/LOW/OPEN for the scanner channel 3-17,
3-26, 3-35

I

IDATA (IDAT) 3-38
IMAGDATA (IMAG) 3-40
imaginary current 3-40
initialization 3-2
inserts a memory number into the specified step
3-67
INVALID (INV) 3-6
invalid-setting register 3-6, 3-73
IR:CONTACTCHECK (I:CCH) 3-37
IR:GND (I:GND) 3-33
IR:LOWER (I:LOW) 3-30
IR:MEMORY (I:MEM) 3-60
IR:RECALL (I:REC) 3-53
IR:RISETIME (I:RTIM) 3-32
IR:SCAN (I:SCAN) 3-35
IR:SCANW (I:SCANW) 3-36
IR:STORE (I:STOR) 3-54
IR:TESTV (I:TES) 3-29
IR:TIMER (I:TIM) 3-31
IR:UPPER (I:UPP) 3-31
IR:WAITTIME (I:WTIM) 3-33

L

L FAIL 3-48
list of GPIB functions 2-1
LOW/GUARD of the GND 3-16, 3-25, 3-33
lower current 3-10, 3-21
lower resistance 3-30

M

MEASMODE (MMOD) 3-42
message 2-3, 3-74
MOMENTARY 3-44
MOMENTARY (MOM) 3-44
MON 3-40
monitor current 3-38
monitor resistance 3-39
monitor voltage 3-38

O

offset 3-13
ON/OFF of the contact check function 3-19,
3-28, 3-37
ON/OFF of the lower judgment function 3-10
ON/OFF of the timer function 3-12, 3-22
output-voltage range 3-15

P

parity 1-4
PASS 3-47
PASS hold time 3-43
PASSHOLD (PHOL) 3-43
POWER ON 3-50
PRGDEL (PDEL) 3-68
PRGEDIT (PED) 3-64
PRGINS (PIN) 3-67
PRGNAME (PNAM) 3-63
PRGNEW (PNEW) 3-66
PRGRETURN (PRET) 3-66
PRGTEST (PTES) 3-64
PRGTOTAL (PTOT) 3-67
program 3-64
program messages 2-3

program name 3-63
program-message terminator 2-5
PROTECT 3-49
PROTECTION (PROT) 3-6, 3-7
protection register 3-7
protection register 1 3-72
protection register 2 3-72

R

RDATA (RDAT) 3-39
READY 3-48
real current 3-39
REALDATA (REAL) 3-39
recalls the contents of memory 3-52, 3-53
response-message terminator 2-5, 3-8
RETURN 3-66
ROM version 3-2
RS-232C cable 2-1
RS-232C flow control 2-2
RS-232C pin assignment 2-2

S

SCANTYPE (STYP) 3-41
service-request enable register 3-3, 3-71
set and reset each register 3-1
set the specified program 3-64
SIGCFAIL (SCF) 3-50
SIGHVON (SHV) 3-46
SIGLFAIL (SLF) 3-48
SIGPASS (SPAS) 3-47
SIGPOWERON (SPOW) 3-50
SIGPROTECTION (SPR) 3-49
SIGREADY (SREA) 3-48
SIGTEST (STES) 3-46
SIGUFAIL (SUF) 3-47
SILENT (SIL) 3-7
special symbols and characters 3-1
START 3-8
start voltage 3-13, 3-23
starts a test 3-8
status byte register 3-3, 3-71

STOP 3-8
stop bit 1-4
stops a test 3-8
store the current settings 3-53, 3-54
structure of status data 3-70
system configuration (example) 1-1

T

terminator 2-5
TEST 3-46
test frequency 3-10
test time 3-12, 3-22, 3-31
test time elapsed 3-40
test voltage 3-9, 3-20, 3-29
the number of valid connected channels 3-41
the step currently executed by the program 3-69
TIME 3-40
TOS6200 1-2
total number of steps 3-67
TRM 3-8

U

U FAIL 3-47
upper current 3-11, 3-22
upper resistance 3-31

V

VDATA (VDAT) 3-38
voltage fall time 3-14
voltage rise time 3-14, 3-24, 3-32

W

WAIT TIME 3-24, 3-33



If you find any misplaced or missing pages in the manuals, they will be replaced. If the manual gets lost or soiled, a new copy can be provided for a fee. In either case, please contact your Kikusui agent or distributor. At that time, inform your agent or distributor of the "Part No." written on the front cover of this manual.

Every effort has been made to ensure the accuracy of this manual. However, if you have any questions or find any errors or omissions, please contact your Kikusui agent or distributor.

After you have finished reading this manual, store it so that you can use it for reference at any time.

KIKUSUI ELECTRONICS CORP.

1-1-3 Higashiyamata, Tsuzuki-ku, Yokohama,
224-0023, Japan
Tel: +81-45-482-6353 Fax: +81-45-482-6261



Website

<http://www.kikusui.co.jp/en>